

Application for City Building Permit

TO THE ENFORCING OFFICER OF NAPOLEON, OHIO

Application No. 26 Date March 7 1956

NAME OF APPLICANT Burdette Rausch

PHONE 23721

ADDRESS 811 First St.

NAME and ADDRESS of OWNER Burdette Rausch

Napoleon Ohio

811 First St Napoleon Ohio

LOCATION OF PROPERTY — LOT NO. 16

IN Huddle add. ADDITION

STREET NO. or OTHER DESCRIPTION OF LOCATION

811 First St Napoleon Ohio

PRESENT USE OF PROPERTY Dwelling

PROPOSED USE Car Port

ZONING CLASS OF PROPERTY F

CONTRACTOR Burdette Rausch

ADDRESS 811 First St Napoleon Ohio

SHOW ALL DETAILS ON SKETCH BELOW

Estimated Cost \$280.00

Lot Dimensions 74 X 160

Lot Area, Sq. Ft. 11840

Bldg. Size 16 X 24

Sq. Ft. 384

Front Yard 25 X 74

Side Yard 8 X 36

Off St. Parking _____

Off St. Loading _____

Type Of Const. Wood

New Addition


Location Of Sewer or

Septic Tank Sewer in

Front of House

Location Of Water Tap

Front of House



BUILDING PERMIT NO. 26 ISSUED 3/7/57 DENIED

IF DENIED, STATE REASONS _____

CERT. OF OCCUPANCY NO. _____ ISSUED _____

INSP. DATE _____

IF DENIED — STATE REASONS _____

BOARD ACTION REQUESTED _____

COMM. ACTION REQUESTED _____


I hereby declare that the above and attached information is correct, and agree, in consideration of and upon issuance of a building permit, to do or allow to be done only such work as herewith applied for and such premises and its existing and proposed buildings and structures shall be used or allowed to be used for such purposes as set forth above.

Signed by Burdette Rausch Address 811 First St Napoleon Ohio

hereby declares that he has been duly authorized by the Owner/Lessee to make the above application and permit.



7-15-86



REQ. FOR PERMIT

~~DECK~~

*

PLUMBING ISOMETRIC & PLAN
PLUMBING CONTRACTOR
~~ELECT. PLAN~~
HEATING PLAN
~~PLUMB~~

1- ADD COPY OF DWG # 2

WINDOWS O.K.

FLOOR VOISYS OK

CHECK
w/ron *

CEIL. VOISYS NOT ADEQUATE

*

INSULATION 3 1/4" WALL 12" CEIL HOOSI
8" CEIL GARAGE

*

15# ROOFING FELT

*

WHAT FRAMING OVER GARAGE.

*

HEADR SIZE - GARAGE DOOR

→

6" J 12.5 = 118 WC

118 ÷ 14 = 8.43 RW

13' x 14' = 182 S.F. = 96,72 CBS, P, S, F,

*

50# MIN. LOAD

*

WHAT GRADE OF LUMBER - RAFTERS MIN 1200
YELL

*

TYPE OF INTERIOR FINISH S1

*

SECTION THRU BRICK

*

TYPE OF SHEATHING

↳

SECTION THRU GARAGE

ISOPLY
7/16" PART. PD. ROOF
3/4" T+G PCW. FLOOR