

PERMIT

City of Napoleon  
255 W. Riverview  
Napoleon, OH 43545

Division of Building and Zoning  
PH (419) 592-4010  
FAX (419) 599-8393

Permit No: 002303

Date Issued: 08-02-04

Issued by: BND

Job Location: 600 FREEDOM DRIVE

Est. Cost:

Lot #:

Subdivision Name:

Owner: FIRST CALL FOR HELP  
Address: 1330 SCOTT ST  
CSZ: NAPOLEON, , OH 43545  
Phone:

Agent: MIDWEST CONTRACTING  
Address: 8300 AIRPORT HWY, SUITE 2  
CSZ: HOLLAND, OH 43528  
Phone: 419-866-4560

Use Type -- Residential:

Other:

ZONING INFORMATION

Dist: Lot Dim: Area: Fyrd: Syrd: Ryrd:  
Max HT: # Pkg Spaces: # Loading SP: Max Lot Cov:

BOARD OF ZONING APPEALS:


Work Type -- New: Replmnt: Addn'n: Alter: Remodel:

WORK INFORMATION

Size - Lgth: Width: Stories: Living Area SF:  
Garage Area SF: Height: Bldg Vol Demo Permit:

WORK DESCRIPTION  
WATER TAP ONLY

FEE DESCRIPTION  
WATER TAP PERMIT



FEE AMOUNT DUE  
2694.06

Total Fees Due 2694.06

Date

Applicant Signature

**2" METERING FOR 1<sup>ST</sup> CALL FOR HELP**

<u>ITEM</u>	<u>COST</u>
2" compound meter	\$1,413.00
2" strainer	\$142.35
2 – wall mount MIU @ \$80/ea	\$160.00
2" coppersetter	<u>\$400.00</u>
	\$2,115.25
25% upcharge	<u>\$528.81</u>
Sub-total #1	\$2,644.06
<u>LABOR</u>	
meter installation 2 men – 1 hr @ \$25/hr/ea	<u>\$50.00</u>
Sub-total #2	\$50.00
Sub-total #1	\$2,644.06
Sub-total #2	<u>\$50.00</u>
TOTAL	\$2,694.06
<b>GRAND TOTAL</b>	<b><u>\$2,694.06</u></b>

Double check valve detector required on fireline, reduced pressure assembly required on potable.

**\*\* NOTE:** City to provide hydrant on end of line. Pressure test to be done on water main as well as 8" fireline.

Sample tap to be made at end of line near valve as per City specifications.

Sample point will need to be installed inside building on 8" fireline.

Sample point to be installed on 2" potable water line inside building.

All work to be done per City specifications.