

CITY OF NAPOLEON

BUILDING CONSTRUCTION PERMIT

Owner Name Leon J. Carrascal  
Address 133 E. Front St.  
Builder Name Self  
Address ..... Tel. ....

Lot Information:

Street No. 133 E. Front St.  
Lot 4 Subdivision City Plat  
Lot Dimensions ..... Lot Area ..... Sq. Ft.  
Yard Set Back: Front ..... Rear .....  
Side ..... Side .....

Sidewalk required in accordance with Ordinance  
No. Zoning "GB."

Building Information:

Residence  Commercial ..... Industrial .....  
Single ..... Double ..... Multiple ..... New Construction ..... Addition ..... Remodel .....  
Size: Length ..... Width ..... No. of Stories .....  
Floor Area: 1st Floor ..... 2nd Floor ..... 3rd Floor ..... Basement .....  
Unfinished Attic ..... Garage .....  
Foundation: Piers ..... Full Basement ..... Part Basement .....  
Concrete ..... Block .....  
Walls: Frame ..... Block ..... Brick ..... Other .....  
Electrical Outlets: 120v ..... 240v .....  
Plumbing: Fixtures ..... Traps ..... Vents ..... Heating ..... Air Conditioning .....  
Additional Information: City to spot location of service suspension point

Date 7/27/74 Applicant Signature Leon J. Carrascal  
Owner - Builder - Agent

Inspection Record:

Work Started ..... Foundations ..... Plumbing, Heating .....  
Set Back, Side Lines ..... Plumbing (Rough In) ..... And Air Conditioning .....  
Excavation ..... Erecting Frame ..... Roof .....  
Footing ..... Electrical Work inspected by Bob Meyers on 7/30/74

Comments: ok except ground wire to ground post in meter box.  
L.W.P.

Certificate of Occupancy Issued .....

Pink - Engineer

Inspector

Permit No.	<u>85</u>			
Issued	<u>7-17-74</u>			
By	<u>P.H. Baulman</u> Building Inspector			
Estimated Cost	<u>7,200.00</u>			
	<b>Fees</b>	<b>Base</b>	<b>Plus</b>	<b>Total</b>
Construction				
Basement				
Detached Garage				
Plumbing				
Electrical		<u>500</u>	<u>-</u>	<u>500</u>
Heating				
Air Conditioning				
Water Tap				
Sewer Tap				
Temporary Electric				
Total				<u>500</u>

CITY OF NAPOLEON

255 W. Riverview

NAPOLEON, OHIO 43545

message

reply

to: Leon J. Coressel  
133 E. Front St.  
Napoleon, Ohio 43545

subject Electrical Inspection, Permit No. 85

ON Friday, July 26, 1974, an  
inspection was conducted on the  
installation for a new electrical  
entrance and the following condition  
was noted:

Ground, ground to ground post  
in meter box.

Taken Care of  
8/1/74 J.W.P.

date July 29, 1974 signed Thomas Bronson  
City Building Inspector

date \_\_\_\_\_ signed \_\_\_\_\_

SENDER: Mail white and pink copies with carbon intact.  
#33990, Amsterdam Printing and Litho Corp., Amsterdam, N.Y. 12010

RECEIVER: Reply, retain white copy, return pink copy.