

CITY OF NAPOLEON
BUILDING CONSTRUCTION PERMIT
 (1, 2 or 3 Family Dwelling)

Owner Name Mrs. Carl Walters
 Address 222 E. Front St.

Builder Name Jim Speiser Electrical Co.
 Address P.O.#2, Napoleon Tel. 599-1846

Lot Information:

Street No. 222 E. Front St.
 Lot #26 Subdivision Original Plat lot.
 Lot Dimensions _____ Lot Area _____ Sq. Ft.
 Yard Set Back: Front _____ Rear _____
 Side _____ Side _____

Zoning "GB" Intended use of Building: Installing in the same location of the existing services the following: 100AMP. services with main disconnect and panel below the meter can.

Building Information:

Single Double _____ Multiple _____ New Construction _____ Addition _____ Remodel
 Size: Length _____ Width _____ No. of Stories 2
 Floor Area: 1st Floor _____ 2nd Floor _____ 3rd Floor _____ Basement _____
 Unfinished Attic _____ Garage _____
 Foundation: Piers _____ Full Basement _____ Part Basement _____
 Concrete _____ Block _____
 Walls: Frame _____ Block _____ Brick _____ Other _____
 Electrical: Wiring _____ Electric Heating _____ Electrical Appliances _____
 Plumbing: Fixtures or Traps _____ Warm Air Heating _____ Hot Water Heating _____

Additional Information: this permit requires compliance with the attached addendum marked exhibit "A" and made a part here-of.

Date 6-16-75 Applicant Signature Jim Speiser
 Owner - Builder - Agent

Inspection Record:

Work Started _____ Foundations _____ Plumbing, Heating _____
 Set Back, Side Lines _____ Plumbing (Rough In) _____ And Air Conditioning _____
 Excavation _____ Erecting Frame _____ Roof _____
 Footing _____ Electrical Work _____

Comments: possible New c/B defective. Speiser informed 6/19/75 by fwp.

Certificate of Occupancy Issued _____

Pink - Engineer

Inspector

Permit No.	<u>297-75</u>		
Issued	<u>6/23/75</u>		
By	<u>James E. Howes</u> Building Inspector		
Valuation	<u>\$300.00</u>		
	Fees	Base	Plus
Construction	---	---	---
Plumbing	---	---	---
Electrical	<u>\$3.00</u>	<u>\$2.35</u>	<u>\$5.35</u>
Heating	---	---	---
Water Tap	---	---	---
Sewer Tap	---	---	---
Temporary Elec.	---	---	---
TOTAL	<u>\$3.00</u>	<u>\$2.35</u>	<u>\$5.35</u>

1.75 1st 16 Circuits
360 1st 16
535

CITY OF NAPOLEON
ENGINEERING DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(PLEASE PRINT OR TYPE)

The undersigned hereby makes application for the installation, replacement, or alteration of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Code for 1, 2 and 3 Family Buildings.

Owner's Name Mrs Carl Walters Address 222 E. Front St
Contractor's Name Jim Spaiser Electric Address _____ Tel. 597-1846

LOT INFORMATION:

Location of Project _____ Zoning District _____

BUILDING INFORMATION:

Single Family _____ Double Family Multiple Family _____
New Construction _____ Existing _____ Addition _____
Replacement of 1 service Remodel _____ Service Change
Size: Total Square Foot Per Floor _____ No. of Stories _____

DESCRIPTION OF WORK

Size of Service 100 AMP. Service Change Only _____ (Yes or ~~No~~)

Total Number of New Circuits 16 Total Number of New Circuits Excluding Appliance Circuits _____

APPLIANCE CIRCUITS: (indicate quantity)

Electric Range _____ Range Hood _____ Clothes Dryer _____ Dishwasher _____
Air Conditioner _____ Attic Fan Blower _____ Room Exhaust Fan _____
Disposal _____ Hot Water Heater _____ Electric Oven _____
Require Temporary Electric _____ (Yes or No)

Note: G.F.I.C. required for all temporary electric with approved ground rod at service.

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAY-OUT AND RISER DIAGRAM.

ESTIMATED COST OF COMPLETED PROJECT: \$300.00

DATE 6-13-75 APPLICANT'S SIGNATURE Jim Spaiser
OWNER CONTRACTOR-AGENT

Main Disconnect with panel below meter

CITY OF NAPOLEON
ENGINEERING DEPARTMENT
APPLICATION FOR CONSTRUCTION PERMIT
(PLEASE PRINT OR TYPE)

The undersigned hereby makes application for the construction, installation, replacement or alteration as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's Building Code for 1, 2 and 3 Family Buildings.

Owner's Name HERMIT THOMPSON Address 620 SHEFIELD, NAD.
Builder's Name MAXD. REIMUND Address MALINTA, O Tel. 256-7240

LOT INFORMATION:

Location of Project 620 SHEFIELD Lot # _____
Subdivision _____ Lot Area _____ Sq. Ft. _____
Yard Set Back: Front _____ Rear _____ Left Side _____
Right Side _____ Zoning District _____

BUILDING INFORMATION:

Single _____ Double _____ Multiple _____ New Construction _____
Addition _____ Remodel _____ Attached Garage _____
Detached Garage _____ Accessory Building _____ Replacement ROOF.

Description of Building RE-ROOF HOUSE REMOVING CEDAR SHINGLES,
REPLACE 3/8 PLYWOOD, 15 LB PAPER, ASPHALT SHINGLES,
Specific Occupancy Use BUILDING UP REAR DECK, GIVING MORE PITCH,
MAY BE CLOSE DOOR TO DO SO.

Size: Length _____ Width _____ No. of Stories _____
Floor Area: 1st Floor _____ Sq. Ft. 2nd Floor _____ Sq. Ft.
3rd Floor _____ Sq. Ft. Basement _____ Sq. Ft.
Unfinished Attic _____ Garage _____

Foundation: Piers _____ Full Basement _____ Part Basement _____
Concrete _____ Thickness _____ Block _____ Size _____

Walls: Frame _____ Block _____ Brick _____ Other _____
Specific Type of Exterior Siding _____

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELEVATIONS, FLOOR PLANS, CROSS SECTIONS AND PLOT PLAN. IF ADDITIONS OR REMODELING, SHOW ALL EXISTING STRUCTURES AND THEIR SIZE AND LOCATION. **ALL PLANS SHALL BE DRAWN TO SCALE.**

ESTIMATED COST OF COMPLETED PROJECT: 1800.00

DATE _____ APPLICANT'S SIGNATURE _____
OWNER-BUILDER-AGENT _____

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545
(Please Print or Type)

Date June 19, 1975

Permit No. 297-75

Type of Inspection Service

Type of Occupancy Two Family

Project Name Mrs. Carl Walters

Address 222 East Front St.

City Napoleon State O.

Approved

Violation X

Electrical Contractor

Remarks:

Code Reference

New Service	
1- NM cable not to be used in wet or damp locations	336-3
2- Splices not in enclosure	300-15(a)
3- Check 1/2 C/B connection on red conductor, may be defective C/B	
EXISTING SERVICE	
① NM cables in wet or damp locations	336-3
② Splices in NM cable	
③ over current protection for conductors	310-24
④ adequate protection for SE cable	336-6
⑤ adequate routing of SE cable	336-1

Compliance Time

Inspectors Signature N. Howell

Copies To: John Fuchey - Fire Inspector GIVEN To John 6/20/75-Ruf

White - Applicant Yellow - Engineering Pink - Electrical Inspector

