

# City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE - (419) 592-4010  
NAPOLEON, OHIO 43545-0151



Mayor  
Steven Lankenau

Members of Council  
James Hershberger, President  
Terri A. Williams  
John E. Church  
Randy J. Bachman  
Matthew G. Gloor  
Robert G. Heft

City Manager  
Terry Dunn

Finance Director  
Rupert W. Schweinhagen

Law Director  
Michael J. Wesche

Prosecuting Attorney  
Thomas L. Bischoff

May 30, 1990

Mr. Denny Meyer  
Ed Rohrs Realty  
712 North Perry  
Napoleon, Ohio 43545

Re: Ken Robertson  
Sanitary Sewer Violation  
240 West Front Street  
Napoleon, Ohio

Dear Mr. Meyer:

The City of Napoleon recently completed some storm sewer improvements along the Front Street right-of-way to correct drainage problems adjacent to the above mentioned building.

During this work, Mr. Helberg from our Inspection Department, noticed several sanitary sewer structures that will require the Owner's immediate attention.

These structures are open access to storm water from surface runoff, which creates unwanted storm water from entering our sanitary sewer system.

We have enclosed three (3) pictures, which illustrate the problem areas around the building.

Picture #1: Is an old grease trap/interceptor that outlets directly into the sanitary sewer. You will notice that the lid rim has been broken to drain water that stands in this area.

Pictures #2 & #3: Indicate open cleanouts that allow excessive storm runoff into the existing sanitary sewer. In addition, these open holes constitute a liability hazard to the public.

We would appreciate a response in writing to this office by June 22, 1990.

If you have any further questions, please call.

Respectfully,

Marc S. Gerken, P.E.  
City Engineer

Enclosure

cc: Sonny Helberg



MSG:skw