2015

INVESTIGATION OF ILLEGAL SEWER CONNECTIONS. REVEALED ONE ILLEGAL CONNECTION EXISTED. IT HAS BEEN CORRECTED AND ALL ARE IN COMPLIANCE AT THIS TIME.

231 GARDEN STREET

N
1"= 20'

225

231

MECHANICAL PLUG + CEMENTED

x ok
x ok
x ok
x ok

8" San.

GARDEN STREET

12