City of Napoleon

BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

Property Address:	2400 G/	en arbor Ct.	Welczare	Center	Zip: 43545				
Property Address: 2400 Glen arbor Ct. Welcance Center Zip: 43545 Business Name Glen arbor CTs.									
Contact Person:	DACK	Hawley		Title: 50 pere Terox ot 2-18-99					
Phone Number:	599-217)	Date of Test:	2-18-99					
DEVICE INFORMATION									
Type (circle one)	RP	(DC)	VB	RPDA	DCDA				
Manf/Model: Watts 007 m2 QT Size: 3/4" Serial No.: 83086									
Location of Device Regt reen Walcome Center neg- furnace									
	Differential Gauge ☐ Sight Tube ☐								
Outlet	Reduced Pressure	Assembly		Pressure Vacuum Breaker					
Valve									
Holding X	Double Check Valve		Relief Valve	Air Inlet	Check Valve				
Failed	1st Check	2nd Check	a Calendaria						
				(6)					
Test	DC /O psi	DC 10 psi	Opened at	Opened at	Held at				
Results Pass			psi	psi	psi				
	Apparent			F	P5.				
	RPpsi								
	Actual		Did Not	Did Not	Leaked				
	RP psi		Open	Open					
Date:	Pass 💹	Pass 🔄	Pass	Pass 🗆	Pass 🗆				
2-18-99	Failed	Failed	Failed	Failed	Failed				
Repairs &									
Materials									
			Opened At	Opened At	Held At				
Test After	DC psi	DC psi	psi						
Repairs	ps.	psipsi	Did Not	Did Not	psi				
, and a second	RP psi	RPpsi	Open	Open	Leaked				
	Poi	psipsi	Орен 🗀	Open 🗆	Leakeu				
Date:	Pass	Pass 🗆 🗆	D						
Date.			Pass		Pass				
	Failed	Failed	Failed	Failed	Failed				
Foster Signature The delle F. J.									
Tester Signature: Certification No. 2884									
Owner/Representative Signature:									
)	The state of the s						

City of Napoleon

BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

Property Address:	2400 Ble	n Arber CT.	bldg #1		Zip: 43545				
Business Name	Chan Anhana								
Contact Person	JACK HA	wey		Title: Succesion part					
Phone Number:	Jack Hawley Title: 5 99-2131 Date of Test: 2-18-99								
DEVICE INFORMATION									
Type (circle one)	RP	DC	VB	RPDA	DCDA				
Manf/Model Walts Cog M2 QT Size: 1/2" Serial No.: 35819									
Location of Device under steps in meter closet									
Type of Test Differential Gauge Sight Tube									
Outlet	Reduced Pressure	Assembly	Pressure Vacuum Breaker						
Valve	Tossure Vacuum Breaker								
Holding X	Double Check Valve		Relief Valve	Air Inlet	Check Valve				
Failed	1st Check	2nd Check		Tan Amor	CHOOK VAIVE				
Test O	DCpsi	DCpsi	Opened at	Opened at	Hold of				
Test Results	psi	psi psi	3 2 psi		Held at				
	Apparent		<u> </u>	psi	psi				
	RP 7./ psi								
	Actual		DidNia	D'IN					
7	RP 7.9 psi		Did Not	Did Not	Leaked				
Data		D	Open	Open					
Date: 2-18-99	Pass 🔄	Pass 🗶	Pass K	Pass	Pass				
	raned Li	Failed	Failed	Failed	Failed				
Donaine &									
Repairs &									
Materials									
			Opened At	Opened At	Held At				
Test After	DCpsi	DC psi	psi	psi	psi				
Repairs			Did Not	Did Not					
	RPpsi	RPpsi	Open \square	Open	Leaked \square				
Date:	Pass	Pass 🔲	Pass 🔲	Pass	Pass				
	Failed	Failed	Failed		Failed				
Tester Signature: Thursdall I. John Certification No. 2884									
Owner/Representative Signature:									
The state of									