

PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. 0980 Date 25FEB85

Job Location 1075 Glenwood Avenue Valuation \$ 600,000.00

Owner St Paul Lutheran Church and School Address 1075 Glenwood Avenue

Contractor _____ Telephone No. _____

Address _____

Electric Contractor _____

Plumbing Contractor _____

Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:

Residential _____ Commercial A4 Industrial _____

New Construction _____ Addition A4 Remodel _____

Brief Description of Work Classroom Addition

ISSUED BY _____ DEPT. OF BUILDING & ZONING

PAID

FEB 25 1985

It is the owners or contractors responsibility to call the Building Department for the following (X) inspections:

- Footing excavation prior to placing concrete.
- Footing drains and foundation prior to backfill.
- Prepared sub-grade prior to placing concrete floor slab.
- Sanitary sewer
- Rough-in electrical, plumbing and service framing prior to installing wall board.
- Final electrical, plumbing and heating.
- Final building inspection, prior to occupancy.

PERMIT & FEES OF NAPOLEON

Building Permit	\$ 300.38 <u>305.38</u>
Electrical Permit	\$ <u>102.14</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other	\$ _____
TOTAL FEES	\$ <u>407.52</u>
LESS FEES PAID	\$ <u>-0-</u>
BALANCE DUE	\$ <u>407.52</u>

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. 0380 Date 25 FEB 1985
Job Location 1075 Glenwood Avenue Valuation \$ 600,000.00
Owner St Paul Lutheran Church and School Address 1075 Glenwood Avenue
Contractor _____ Name _____ Telephone No. _____
Address _____
Electric Contractor _____
Plumbing Contractor _____
Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:

Residential _____ No. dwelling units _____ Commercial A4 Industrial _____
New Construction _____ Addition A4 Remodel _____
Brief Description of Work CLASSROOM ADDITION

ISSUED BY _____ Building Official _____ DEPT. OF BUILDING & ZONING

PAID
FEB 25 1985
CITY OF NAPOLEON

It is the owners or contractors responsibility to call the Building Department for the following (X) inspections:

- XXXX Footing excavation prior to placing concrete.
- XXXX Footing drains and foundation prior to backfill.
- XXXX Prepared sub-grade prior to placing concrete floor slab.
- XXXX Sanitary sewer
- XXXX Rough-in electrical, plumbing and service framing prior to installing wall board.
- XXXX Final electrical, plumbing and heating.
- XXXX Final building inspection, prior to occupancy.

PERMIT & FEES

Building Permit	\$ <u>309.38</u>
Electrical Permit	\$ <u>102.14</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ <u>1</u>
Other _____	\$ _____
TOTAL FEES	\$ <u>407.52</u>
LESS FEES PAID	\$ <u>-0-</u>
BALANCE DUE	\$ <u>407.52</u>

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

INSPECTION RECORD

UNDERGROUND			ROUGH-IN			FINAL		
Type	Date	By	Type	Date	By	Type	Date	By
PLUMBING	Sewer Connection		Drainage, W. & Vent			Drainage, W. & Vent		
	Building Sewer		Water Piping			Water Heater		
	Water Piping		Condensate Lines			Backflow Prevention		
			Indirect Waste					
						FINAL APPROVAL		
ELECTRICAL	Floor Ducts Raceways		Rough Wiring			Electric Mtr. Clearance		
	Conduits & Cable		Conduits/Cable			Signs		
	Grounding & Bonding		Service Panel					
			Subpanels					
			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			FINAL APPROVAL		
MECHANICAL	Refrigerant Piping		Refrigerant Piping			Duct Insulation		
	Ducts/Plenums		Ducts/Plenums			Chimney(s)		
			Ventilation Supply			Furnace(s)		
			<input type="checkbox"/> Exhst.			FINAL APPROVAL		
	Location, Set-backs, Esmt(s)		Wall Construction			Fireplace Chimney		
	Excavation		Crawl Space			Attic		
	Footings & Reinforcing		<input type="checkbox"/> Vent <input type="checkbox"/> Access			<input type="checkbox"/> Vent <input type="checkbox"/> Access		
	Sub-soil Drain		Floor System(s)			Special Insp Reports Rec'd		
	Foundation Walls		Roof System			Smoke Detector		
	Floor Slab		Fire Wall(s)			Demolition (sewer cap)		
			Roof Cover			Building or Structure		
			Roof Drain					
	FINAL APPROVAL BLDG. DEPT.		Certificate of Occupancy Issued			#		

5/20/85 South footer poured
East footer ready to pour
pour rest P.M.

5/21/85 NE Footer + SW Footer poured
5/24/85 Formers for columns beyond
block.

6/11/85 Sewer underground

6/15/85 Floor fill for basement

6/24/85 wall pour in job

6/24/85 Rough elect. office area
Hand beam fabricator

6/26/85 Footer east portion

6/27/85 Footer east portion

8/12/85 General Brick

8/24/85 Rough Elect and Basement
Brick work + slab.

9/11/85 Pour Footers

9/14/85 " "

9/19/85 " "

11/19/85 Final Elect. RYH

PROJECT RECORD FORM

JOB NUMBER _____

DATE	REMARKS
15 JUL 85	ROB GIDDENS BUEHRER GROUP 893-9021 893-1795
	DOW CHEMICAL USA ; STYROFOAM SM INSULATION
	CAN THIS BE USED IN AN EXTERIOR WALL CONSISTING
	OF 8" MASONRY, 3" DOW BOARD, 4" MASONRY & 15 MIN
	THERMAL PROTECTION, IN AN INSTITUTIONAL STRUCTURE
	TYPE 2B CONSTRUCTION
	I LOOKED IT UP , WE ARE MISSING RESEARCH REPORT
	NO. 80-72
	I CALLED BOCA, INTL, COUNTRY CLUB HILLS, ILLINOIS
	(312) 799-2300 [SARAH RICE]
	SARAH RICE DETERMINED THAT DOW BOARD, TYPE SM,
	IS PERMITTED IN THIS INSTANCE; THERMAL PROTECTION
	IS NOT REQUIRED
	SHE WILL SEND US RESEARCH REPORT NO. 80-72.

Paul E. Buehner

05 AUG 85 RECEIVED RESEARCH REPORT NO. 80-72



