

Certificate of Occupancy

Wood County Building Inspection

<p>Address: ST. PAUL LUTHERAN CHURCH & SCHOOL 1075 GLENWOOD AVENUE NAPOLEON, OH 43545 County: Henry</p>	<p>Stipulations, Conditions, & Variances: Health/Safety Only. Existing Rooms C101 and C102 are changed to E-Use Group. Maximum Occupancy Approved per Room is 18 for Children older than 2 1/2 years of age..</p>												
<p>Approved As:</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;">Use Groups:</th> <th style="width: 70%;">Occupancy Description:</th> </tr> </thead> <tbody> <tr> <td>Primary</td> <td>E Educational</td> </tr> <tr> <td>Accessory</td> <td>0</td> </tr> <tr> <td>Accessory</td> <td>0</td> </tr> <tr> <td>Accessory</td> <td>0</td> </tr> <tr> <td>Mixed Use</td> <td>0</td> </tr> </tbody> </table> <p>Attached Floor Plan: []</p>	Use Groups:	Occupancy Description:	Primary	E Educational	Accessory	0	Accessory	0	Accessory	0	Mixed Use	0	<p>This Certificate represents an approval that is valid only when the building and its facilities are used as stated and is conditional upon all building systems being maintained and tested in accordance with the applicable Ohio Board of Building Standards rules and applicable equipment or systems schedules. This certifies conformance with Chapters 3781 and 3791 of the Ohio Revised Code and the applicable provisions of the rules of the Ohio Board of Building Standards.</p>
Use Groups:	Occupancy Description:												
Primary	E Educational												
Accessory	0												
Accessory	0												
Accessory	0												
Mixed Use	0												
<p>Construction Type: Sprinklers</p>	<p>System Type: Demand: Standpipe: Demand:</p>												
<p>Location:</p> <p>Specific Hazards: Existing Fire Alarm Systems is Required to be Monitored, Tested, and Certified Annually for this Occupancy to Remain Valid.</p>	<p>OBC Ed. 2011 OMC Ed. 2011 OPC Ed. 2011 Health and Safety OBC Section 111.1 Plan Approval/Building Permit No: C15-000270 Date: 04/07/2016 Chief Building Official: Michael J. Rudey</p>												