

DATE: 5-12-15

INSPECTED BY: MARTY CROSSANO
INVESTIGATION OF ILLEGAL SEWER
CONNECTIONS. CITY SEWER DEPT.
DYE TESTED CONNECTED DOWNSPOUTS
AND VERIFIED AN OUTLET TO THE
CREEK BEHIND. NO ILLEGAL SEWER
CONNECTIONS ARE PRESENT AT THIS
TIME.

1235 GLENWOOD AVENUE

NOTE: ALL PIPE LOCATIONS
ARE ASSUMED AS ONLY DYE
TESTING WAS DONE AND NOT
LOCATES.

