

CITY OF NAPOLEON

115 W. Main St.
NAPOLEON, OHIO 43545

message

reply

to: [American Legion, Post 300
500 Glenwood Ave.
Napoleon, Ohio 43545]

subject Electrical & Building Inspection

An inspection was conducted on 5-22-74 & the following items need your attention:

Electrical: (by R. Meyer, State Inspector)

- ✓ 1. Enclose the unused openings in the distribution panel.
- ✓ 2. Label the individual breakers of the distribution panel.
- ✓ 3. No storage permitted within 30" of control panels.
- ✓ 4. Secure Greenfield conduit near furnace controls.
- ✓ 5. Secure the hanging wire near the top of furnace.
- ✓ 6. Missing switchbox cover in furnace room.
- ✓ 7. Plug openings in panel in the kitchen area.

Building:

- ✓ 1. Seal the cove base at floor of both restrooms. (BB 21-12(D))
- ✓ 2. Flame resistive ability of wall covering in the bandstand area. BB 7-41, 05.
- ✓ 3. Seal all openings around pipes and ducts which pass through the heater room wall. BB 7-45(E)
- ✓ 4. Tape the joints of furnace room ceiling & enclose the access openings.

5] Plumbing: Show evidence of final inspection approval.

date 5-23-74 signed P.H. Basileman date _____ signed _____

SENDER: Mail white and pink copies with carbon intact.

#33990, Amsterdam Printing and Litho Corp., Amsterdam, N.Y. 12010

RECEIVER: Reply, retain white copy, return pink copy.

2/1/75

Informed Bob Ludiman
item 2&5 remains
to be taken care
of. XW.P.

All other items
inspected & approved
by N. Howes &
Tom Terranova
on 2/6/75