



City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE - (419) 592-4010
NAPOLEON, OHIO 43545-0151

April 29, 1987

Mayor

Robert G. Heft

Members of Council

William Young, President
Lawrence Haase
James Hershberger
Donald Stevens
Donald Morford
Steve White

City Manager

Richard A. Hayward

Clerk-Treasurer

Rupert W. Schweinhagen

Law Director

Keith P. Muehlfeld

Mr. Terry L. Beilharz, A.I.A.
Pastor & Beilharz
701-1/2 West First St.
Defiance, Ohio 43512

RE: American Legion Project
Fire Protection Flow Rates

Dear Mr. Beilharz,

Please find enclosed a map showing the
Waterline and Hydrant locations for the above
referenced project.


Also, the flow test data for the area is as
follows:

Hydrant No. 7 - Test Date 10-30-86
Static 74 PSI
Residual 48 PSI
Rate 1,293 GPM
Location - S.W. corner of Glenwood and
N&W RR.
Feed - 8" Main on West side of Glenwood

Hydrant No. 8 - Test Date 10-30-86
Static 72 PSI
Residual 14 PSI
Rate 698 GPM
Location - N.E. corner of Glenwood and
Welsted
Feed - 4" Main on North side of Welsted

Should there be any questions, please feel
free to call.

Respectfully,


John A. Helberg
Assistant to the
City Engineer