

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Project Name City Pool

Address _____

City NAPOLEON State OHIO

Approved _____

Violation ✓

Electrical Contractor _____

Remarks:

Code Reference

① Receptacle for clock shall be of the grounding type & when within 15 feet of water shall be protected by GFCI

680-6 NEC

② Cord through hole in joist for clock

400-8 NEC

Complied 9-28-78 N.H.

Compliance Time at once

Inspectors Signature Norman Howes

Copies To: _____