

SEWER TAPPING PERMIT

Issued by

The City of Napoleon Engineering Dept.

255 West Riverview Ave. Napoleon, Ohio 43545 Pn. 592-4010

Entry No. _____

Permit No. _____ Issued _____ Build. Permit No. _____

Permit Fee \$ _____

Job Location _____

Street Bond \$ _____

Lot _____

Date Paid _____

sub div. or legal disc.

Issued By _____

Owner _____ Pn. _____

Address _____

Agent _____ Pn. _____

Address _____

for office use only

WORK INFORMATION

Sanitary Sewer Tap _____ Size of Tap _____ Size and Type of Sewer _____ Street to be Opened _____

yes no

yes no

Storm Sewer Tap _____ Size of Tap _____ Size and Type of Sewer _____ Street to be Opened _____

yes no

yes no

Street opening Agreement Approval Date _____ Opening Bond Fee (Set by Engineer) _____

READ AND SIGN BELOW; The undersigned hereby agrees complete the work described above and to make use of said sewers only as allowed by and in strict accordance with all applicable provisions of The Napoleon Engineering Dept. Rules and Regulations, The Napoleon Standard Specification for Water Main, Sanitary Sewer and Storm Sewer Construction and other Pertinent Sections of the Napoleon Code of Ordinances.

Date 4-20-92 Signature of Applicant [Signature]

Permit not valid without signature

INSPECTION RECORD _____ to be completed by the Field Inspector

Date Inspection is made _____ Size and Type of Sewer _____

Location _____ Depth _____ Type of Test _____ Additional Information _____

Date _____ Inspected By _____ signature of inspector

Sketch Of Installation on Back or Attached

4-20-92

Paul Walters

8" Vit cleanout cleaned
of roots lower portion broken
down needs replaced?

Sonny Helberg

824

828

West Graceway

6" P.V.C. Cleanout

4 ft deep

8" Vit cleanout 8" underground
6 ft deep

Cross in curb



