

City of Napoleon
Utility Dept.

592-7771
Probate

255 W. Riverview Avenue
P.O. Box 151
Napoleon, Ohio 43545

Phone: 419-599-1235

Thursday, March 30, 2000

Ms. Deb Rakes
875 W. Graceway Dr.
Napoleon, Ohio 43545

Re: Electric Rules Violations/ Notice of Disconnect

COMPLETED

Dear Ms. Rakes

The City of Napoleon's Building and Zoning Inspector and the Electric Department have attempted to contact you on several different occasions without success in regard to the following violations:

1. National Electrical Code Violations: The electric service drop is routed through the overhang of the second story addition; further, the overhead open air triplex service wires are located indoors, both being prohibited..
2. Electric Rule 4.4 Meter Installation Violation: The meter is not being kept in a place readily accessible for purposes of reading by utility personnel, to wit: fenced.
3. Electric Rule 4.6 (F) Violation: Your property being served is not being kept in good repair and not in accordance with the National Electrical Code.

Be advised: The City has a right to disconnect pursuant to Rule 12 of the Rules Terms and Conditions of Electric Service and therefore, disconnect will occur 14 days after receipt of this letter. You may avoid disconnect by demonstrating to the satisfaction of the Utility Department that all violations have been fully corrected. Please refer to the City's Rules Terms and Conditions of Electric Service regarding any appeal right you may have, a copy of which is available at the City Utility Department. Should you have any questions or comments, please do not hesitate to contact the Utility Office at 419 599-1235.

Sincerely,

Peg Miller
Peg Miller
Utility Department Supervisor

Check today
4-24-00

ElectFormDisconnect L:\LAW\lotus\wordpro\lawdirec\forms 3/30/00 2:38 PM

City of Napoleon
Utility Dept.

592-7771
Probate

255 W. Riverview Avenue
P.O. Box 151
Napoleon, Ohio 43545

Phone: 419-599-1235

Thursday, March 30, 2000

Ms. Deb Rakes
875 W. Graceway Dr.
Napoleon, Ohio 43545

Re: Electric Rules Violations/ Notice of Disconnect

Dear Ms. Rakes

The City of Napoleon's Building and Zoning Inspector and the Electric Department have attempted to contact you on several different occasions without success in regard to the following violations:

1. National Electrical Code Violations: The electric service drop is routed through the overhang of the second story addition; further, the overhead open air triplex service wires are located indoors, both being prohibited..
2. Electric Rule 4.4 Meter Installation Violation: The meter is not being kept in a place readily accessible for purposes of reading by utility personnel, to wit: fenced.
3. Electric Rule 4.6 (F) Violation: Your property being served is not being kept in good repair and not in accordance with the National Electrical Code.

Be advised: The City has a right to disconnect pursuant to Rule 12 of the Rules Terms and Conditions of Electric Service and therefore, disconnect will occur 14 days after receipt of this letter. You may avoid disconnect by demonstrating to the satisfaction of the Utility Department that all violations have been fully corrected. Please refer to the City's Rules Terms and Conditions of Electric Service regarding any appeal right you may have, a copy of which is available at the City Utility Department. Should you have any questions or comments, please do not hesitate to contact the Utility Office at 419 599-1235.

Sincerely,

Peg Miller
Peg Miller
Utility Department Supervisor

ElectFormDisconnect L:\LAW\otus\wordpro\lawdirect\forms 3/30/00 2:38

1 Year Retention Period - LD-011

This is hereby extended

to May 5, 2000.

4-25-00

Brent Dammann
John [Signature]

4-25-00

City of NAPOLEON, OHIO

255 WEST RIVERVIEW AVENUE, P.O. BOX 151
NAPOLEON, OHIO 43545-0151
(419) 592-4010
FAX (419) 599-8393



March 15, 2000

Mayor
Donald M. Stange

Mr. John Schink
875 W. Graceway Dr.
Napoleon, OH 43545

Members of Council
Michael J. DeWit, President
Terri A. Williams
James Hershberger
Travis B. Sheaffer
Char Weber
David F. Miller, Jr.
Glenn A. Miller

City Manager
Dr. Jon A. Bisher

Finance Director
Gregory J. Heath

Law Director
David M. Grahn

City Engineer
Adam C. Hoff, P.E.

Re. Electric service drop and location.

Dear John

I have received complaints from the electric department regarding the electric service to your residence. Upon inspections of the alleged violations, I find the following code violations.

1. The electric service drop may *not* be routed through the overhang of the second story addition. Overhead open air triplex service wires may not be located indoors.
2. Your electric meter must be located so that it is accessible at all times.

The conditions stated herein constitute violations of the City electric rules and the National Electric Code. These issues must be corrected immediately or we will be forced to disconnect the electric service from your home.

Please call me when you receive this letter and let me know when you plan to make the appropriate corrections.

Sincerely

Brent N. Damman
Building Commissioner

COMPLETED