

# APPLICATION FOR PERMIT TO TAP SEWER

(Print or Type)

Owner HENRY WIEMKEN NO. \_\_\_\_\_  
Address 1115 HIGHLAND NAPOLEON BLDG. PERMIT \_\_\_\_\_  
Contractor MARVIN BEHNFELDT PERMIT FEE \$ \_\_\_\_\_  
Address R#4 NAPOLEON Tel. 758-3198 DATE PAID \_\_\_\_\_

for office use only

### LOCATION OF CONNECTION

Street and No. 1115 HIGHLAND Sanitary  Storm \_\_\_\_\_  
Lot No. \_\_\_\_\_ Subdivision \_\_\_\_\_ Size of Tap 6"  
Size and Type of Sewer 4" PLASTIC ORING ALL WORK MUST BE INSPECTED

I certify that the sewer will be used only as indicated and no other Drainage will be connected.  
Date 5-21-79 Signature Marvin Behndt owner-builder-agent  
do not write below this line

### INSPECTION RECORD

Date Inspected 5-21-79 Size and Type of Sewer 4" PVC SDR 35  
Location FRONT OF HSE Depth 6' @ TAP Type of Test N/A  
Inspected and Approved By: [Signature] Inspector Date 5-21-79  
Additional Information \_\_\_\_\_

Send copy to: \_\_\_\_\_

### SKETCH OF INSTALLATION

HOOKED TO 4" VITRIFIED FROM HOUSE AT DEPTH OF 3 FEET  
16' EAST AND 4' NORTH OF FRONT STEP

