

1018-20

Hobson

June 8, 1984

Mrs Virginia Henry
422 E. Oak St.
Wauseon, Ohio

Dear Mrs. Henry:

The City of Napoleon Building Department, on June 8, 1984 received a complaint from Robert Bogart of the Napoleon Police Department concerning your four family house at 1018 & 1020 Hobson Street in Napoleon. Mr. Bogart's complaint was about the condition of the suit's interior. Mr. Holtzberry of the Henry County Health Department, Mike Weller the Napoleon Fire Inspector and myself, inspected your dwelling the same day and the following is what was found on just a walk thru of the units.

1018- Water tank flue disconnected, fumes coming directly into unit.
Space heater chimney not connected properly and not double wall pipe.
Living room ceiling light hanging by wires. Wall switch loose.
Evidence of cockroaches.

1018½--Evidence of mice and cockroaches.
Suit in a dirty condition.
Ceiling has holes.
New wiring needed.
Debris and garbage strewn all over house.
Cigarettes put out on floor.

1020- Evidence of mice and cockroaches.
Suit in dirty condition.
Ceiling has holes.
New wiring needed.

1020½--Light bulb on zip cord in shower. High hazard potential.
Evidence of roaches.
New wiring needed.

The items listed above shall be corrected immediately. Another inspection shall take place on June 20, 1984.
Your cooperation in this matter is appreciated.

cc. Robert Bogart Police Dept.
Mike Weller Fire Dept.
Jim Holtzberry Health Dept.

Yours truly,
Richard G. Hayman
Richard G. Hayman

*Corrected
1/28/85
RJS*