

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01640 Issued 10-10-88
date

Job Location 610 Hobson
address

Lot pt. 56 Original Plat
sub-div or legal discript

Issued By Eldon Huber
building official

Owner Leo Fouty
name tel.

Address 610 Hobson

Agent Howard Hinkle 599-2456
builder-eng.-etc. tel.

Address 604 Hobson

Description of Use Residence

Residential 1
no. dwelling units

Commercial _____ Industrial _____

New _____ Add'n. _____ Alter _____ Remodel X

Mixed Occupancy _____

Change of Occupancy _____

Estimated Cost \$ 200.00

FEES	BASE	PLUS	TOTAL
<input type="checkbox"/> BUILDING			
<input checked="" type="checkbox"/> ELECTRICAL	15.00		15.00
<input type="checkbox"/> PLUMBING			
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> DEMOLITION			
<input type="checkbox"/> ZONING			
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs	Elect. _____ hrs	
TOTAL FEES.....			15.00
LESS MIN. FEES PAID _____			
BALANCE DUE.....			

ZONING INFORMATION N.A.

district	lot dimensions	area	front yd	side yds	rear yd
GB					
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

WORK INFORMATION:

Size: Length _____ Width _____ Stories _____ Ground Floor Area _____

Height _____ Building Volume (for demo. permit) _____ cu. ft.

Electrical: Replace existing with new 100 amp O.H. service.
brief description

Plumbing: _____
brief description

Mechanical: _____
brief description

Sign: _____ Dimensions _____
type

Additional Information: _____

PAID
OCT 17 1988
 CITY OF NAPOLEON

Date OCT 10 Applicant Signature Howard Hinkle
owner-agent

BUILDING INSPECTION DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(Please print or type)

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name LEO FORTY Address 610 HOBSON

Electrical Contractor SELF Telephone No. _____

Address _____

General Contractor _____ Telephone No. _____

Address _____

Location of Project 610 HOBSON Cost of Project _____

Work Information:

Residential 1 Commercial _____ Industrial _____

No. Units

New _____ Service Change Rewiring _____ Additional Wiring _____

Brief Description of Work: _____

Size of proposed service entrance 100 AMP Number of new circuits _____

Type of proposed service entrance _____ Underground _____ Overhead

Require Temporary Electric _____ (Yes or No)

Total Floor Area - Commercial and Industrial only _____ sq. ft.

Additional Information: _____

PERMIT NO.

PERMIT FEE \$

*Ground fault circuit interrupter protection is required on all 120-volt single phase, 15 and 20 amp. Circuits which are part of a temporary electric service; and also on bathroom, outdoor, and garage receptacles in all dwelling units. Art. 220-8 N.E.C.

Application for permit shall be accompanied by two complete sets of plans including: Electrical layout and riser diagram. (For commercial and industrial work only).

ate _____ Applicant's Signature Edward Hunt

