

**FLOYD G. BROWNE AND ASSOCIATES, LIMITED**  
CONSULTING ENGINEERS-PLANNERS



9040-MI-N-16

June 16, 1975

Mr. Pritam Arora  
Building Commissioner  
City of Napoleon  
City Building  
Napoleon, Ohio 43545

SUBJECT: NAPOLEON WAREHOUSE, INC.  
BUILDING ADDITION D AND D-1

Dear Mr. Arora:


I have reviewed the plans for the subject project for Compliance with Chapter BB-71 Storage Buildings of the Ohio Building Code and have approved the structure with notations on the plans.

The building permit for the structure can be issued.

If you have any questions feel free to call.


Very truly yours,

FLOYD G. BROWNE AND ASSOCIATES, LIMITED

  
Robert C. Jones, P.E.

Chief Enforcement Official

RCJ:fbh



CITY OF NAPOLEON  
ENGINEERING DEPT.  
PLAN APPROVAL  
BY: B.J. DATE: 6/16/75

*1175  
Independence  
Dr*

MARION OFFICE  
181 South Main Street  
P.O. Box 587  
Marion, Ohio 43302  
614-383-2187

\* NORTHWESTERN OFFICE  
703 North Perry Street  
P.O. Box 27  
Napoleon, Ohio 43545  
419-592-5771

EASTERN OFFICE  
5276 Fulton Drive  
Canton, Ohio 44718  
216-494-3324

INDIANA OFFICE  
Suite 501, First Savings Tr  
P.O. Box 1218  
Anderson, Indiana 46015  
317-644-3676


YOUNGSTOWN OFFICE  
25 East Boardman  
Youngstown, Ohio 44503  
216-747-3175

MEMBERS  
E. B. Butler, P.E.  
T. J. Dunn, Sr. P.E.  
R. C. Jones, P.E.  
M. L. Koehler, P.E.  
H. R. Lloyd, P.E.  
C. R. Martin, P.E.  
L. E. Rigby, P.E.  
D. L. Tesmer, P.E.  
C. W. Wright, P.E.

ASSOCIATES  
R. M. Blank, P.E.  
G. G. Geis, A.I.P.  
R. L. Haas, C.E.T.  
W. R. Hill, C.E.T.  
J. M. Keevil, P.E.  
T. Kraschinsky, Jr., P.E.  
R. C. Lewis  
D. E. Mackling, P.E.  
A. P. Mahatekar, P.E.  
J. E. Miller, P.E.  
H. L. Mumaw, P.E.  
J. Y. Roberson, P.E.  
F. X. Waldo, P.E.

Floyd G. Browne and Associates, Limited is an equal opportunity employer

\*ADDRESS REPLY TO THIS OFFICE



6.16.75

Submitted To

Pritam 6/16/75  
*R.C. Jones*

MEMO TO: Tom Terranova

SUBJECT: Napoleon Warehouse

FROM: R.C. Jones

Total time for review of Plans

6-13-75 1 hr.

6-16-75 1/2 hr.

Total 1 1/2 hours

R. L. GERMANN, PE, PS

May 30, 1975


CITY of NAPOLEON  
BUILDING DIVISION  
Napoleon, Ohio 43545

CERTIFICATE of COMPLIANCE

Project: Napoleon Warehouse  
Building D and D-1  
Napoleon, Ohio

I hereby certify to the best of my knowledge and belief, that the plans and specifications for the above mentioned project are in compliance with the City of Napoleon zoning ordinances for construction in a I-1 zoning district.

Very truly yours,

  
R. L. Germann, PE, PS

RLG/ek



DATE	Sept. 17, 1975	JOB NO.	279-75
PROJECT	250' X 200' Addition - Warehouse		
LOCATION	50 Industrial Drive		
CONTRACTOR	Krueger Const.	OWNER	Napoleon Warehouse
WEATHER	Cloudy	TEMP.	60° at 10:00 AM ° at PM
PRESENT AT SITE	Tom Terranova - Bldg. Insp. Mr. Krueger - Const. Contractor Norb. Bauman - Owner		

TO

R. L. Germano

1475 Oakwood Ave.

Napoleon, Ohio, 43545

THE FOLLOWING WAS NOTED:

Irregularities in construction practices during loading dock slab pour:

1) Concrete delivered from the mixer truck was very wet. Mr. Krueger's reason for the wet soupy concrete was that his supplier added the water not at his request.

2) The use of un-treated wood grade stakes embedded into the const. slab.

3) Required concrete test specimen cylinders conducted from first batch only.

I informed Mr. Krueger and Mr. Bauman that in the future pours, I will be requiring the following:

1) Concrete consistency within the slump range of 2"-4" as recommended by approved standards of (P.C.A) Portland Cement Association, Sec. BB-5-19

2) Un-treated Lumber after use driven into ground or the use of treated Lumber.

3) For a better reading on compressive strength specimens, conduct tests about midpoint and at end of pour. <sup>10/10 Nab B returned with</sup>

COPIES TO Krueger, Bauman &  
Bob Jones C.E.O. of Dept.

FIELD REPORT

SIGNED Tom Terranova