

PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. _____ Date _____

Job Location 2145 County Road 12 Valuation \$ 4,000.00

Owner NATCO Address Box 288 Napoleon Ohio

Contractor 2145 County Road 12 Telephone No. 599-0065

Address _____

Electric Contractor Seli

Plumbing Contractor _____

Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:

Residential _____ Commercial Mercantile Industrial _____

New Construction _____ Addition _____ Remodel _____

Brief Description of Work 300 Amp Service to One 50 Amp Disconnect for CB Sales Trailer and One 60 Amp Disconnect for Office Trailer

1270 Independence

ISSUED BY Richard R. Hayman DEPT. OF BUILDING & ZONING

It is the owners or contractors responsibility to call the Building Department for the following (X) inspections:

- Footing excavation prior to placing concrete.
- Footing drains and foundation prior to backfill.
- Prepared sub-grade prior to placing concrete floor slab.
- Sanitary sewer
- Rough-in electrical, plumbing and service framing prior to installing wall board.
- Final electrical, plumbing and heating.
- Final building inspection, prior to occupancy.

PERMIT & FEES

Building Permit	\$ _____
Electrical Permit	\$ <u>23.50</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other _____	\$ _____
TOTAL FEES	\$ <u>23.50</u>
LESS FEES PAID	\$ <u>0</u>
BALANCE DUE	\$ <u>23.50</u>

PAID
FEB 21 1985
CITY OF NAPOLEON

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

PROJECT RECORD FORM

JOB NUMBER _____


DATE	REMARKS
------	---------

FEB 85	MELVIN SURPRISE MUST COME IN FOR BUILDING ELECTRICAL PERMITS CONSTRUCTION WILL OCCUR IN DEFIANCE INSPECTIONS MUST BE MADE IN DEFIANCE
--------	--

	RECOMMENDED FLEXIBLE CONDUIT BETWEEN RIGID CONDUIT AND OUTLET INSTEAD OF EXPOSED WIRING FROM CONDUIT TO OUTLET @ 2"
--	---

PAUL BIEHRER

07 FEB 85	APPROVE ABOUT DECISION, called Surprise and informed him, no permit, only inspection when trailer is moved in.
-----------	---



Mobile home supply cord
required