



State of Ohio Environmental Protection Agency

1290 Independence

STREET ADDRESS:

Lazarus Government Center
122 S. Front Street
Columbus, Ohio 43215
October 15, 2003

TELE: (614) 644-3020 FAX: (614) 644-3184

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

Re: Napoleon
Henry County
Application No. 03-15951
Application for Gravity Sanitary Sewers for Best Western
Hotel at 2495 Enterprise Drive
Plans Received August 22, 2003
Revised Plans Received September 15, 2003
From New Dimensions

CERTIFIED MAIL

A.&J., LLC
Attn: Paul Grewal
PO Box 268
Napoleon, OH 43545

Ladies and Gentlemen:

Enclosed is the Ohio EPA Permit to Install which will allow you to install the described source in the manner indicated in the permit. Because this permit contains several conditions and restrictions, I urge you to read it carefully.

The issuance of this Permit to Install is considered to be a final action of the director. Any person who was a party to this proceeding may appeal this action to the Environmental Review Appeals Commission pursuant to Ohio Revised Code 3745.04. To appeal this action, a written notice of appeal, setting forth the action complained of and the grounds for appeal, must be filed with the Environmental Review Appeals Commission at 309 South Fourth Street, Room 222, Columbus, Ohio 43215, within thirty (30) days after the date of this letter. You must also serve a copy of the notice of appeal to the director of Ohio EPA and the Environmental Enforcement Section of the Office of the Attorney General within three (3) days of filing a notice of appeal with the Environmental Review Appeals Commission.

You should note that a general condition of your permit states that issuance of the permit does not relieve you of the duty of complying with all applicable federal, state, and local laws, ordinances, and regulations.

If you have any questions, please contact the Ohio EPA district office to which you submitted your application.

Sincerely

Patti L. Smith, Supervisor
Permit Processing Unit
Division of Surface Water

PLS/dks

Enclosure

cc: Northwest District Office
Henry County Health Department
New Dimensions
City of Napoleon

Bob Taft, Governor
Jennette Bradley, Lieutenant Governor
Christopher Jones, Director

Ohio Environmental Protection Agency

Permit to Install

Application No: 03-15951

Applicant Name: A.&J., LLC
Address: PO Box 268
City: Napoleon
State: OH, 43545


Person to Contact: Ronad D. Sonnenberg
Telephone: 419-599-8335

Description of Proposed Source: Gravity Sanitary Sewers for Best Western Hotel at 2495 Enterprise Drive, Napoleon, Henry County

Issuance Date: October 15, 2003
Effective Date: October 15, 2003

The above named entity is hereby granted a permit to install for the above described source pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described source of environmental pollutants will operate in compliance with applicable state and federal laws and regulations. Issuance of this permit does not constitute expressed or implied assurance that, if constructed or modified in accordance with those plans and specifications, the above described source of pollutants will be granted the necessary operating permits. This permit is granted subject to the following conditions attached hereto.

Ohio Environmental Protection Agency



Christopher Jones
Director
P. O. Box 1049,
122 South Front Street
Columbus, OH 43216-1049

This permit shall expire if construction has not been initiated by the applicant within eighteen months of the effective date of this permit. By accepting this permit, the applicant acknowledges that this eighteen month period shall not be considered or construed as extending or having any effect whatsoever on any compliance schedule or deadline set forth in any administrative or court order issued to or binding upon the permit applicant, and the applicant shall abide by such compliance schedules or deadlines to avoid the initiation of additional legal action by the Ohio EPA.

The director of the Ohio Environmental Protection Agency, or his authorized representatives, may enter upon the premises of the above named applicant during construction and operation at any reasonable time for the purpose of making inspections, conducting tests, examining records, or reports pertaining to the construction, modification, or installation of the above described source of environmental pollutants.

Issuance of this permit does not relieve you of the duty of complying with all applicable federal, state, and local laws, ordinances, and regulations.

Any well, well point, pit, or other device installed for the purpose of lowering the ground water level to facilitate construction of this project shall be properly abandoned in accordance with the provisions of this plan or as directed by the director or his representative.

Any person installing any well, well point, pit or other device used for the purpose of removing ground water from an aquifer shall complete and file a Well Log and Drilling Report form with the Ohio Department of Natural Resources, Division of Water, within 30 days of the well completion in accordance with the Ohio Revised code Section 1521.01 and 1521.05. In addition, any such facility that has a capacity to withdraw waters of the state in an amount greater than 100,000 gallons per day from all sources shall be registered by the owner with the chief of the Division of Water, Ohio Department of Natural Resources, within three months after the facility is completed in accordance with Section 1521.16 of the Ohio Revised Code. For copies of the necessary well log, drilling report, or registration forms, please contact:

Ohio Department of Natural Resources
Fountain Square
Columbus, OH 43224-1387
(614) 265-6717

The proposed wastewater disposal system shall be constructed in strict accordance with the plans and application approved by the director of the Ohio Environmental Protection Agency. There shall be no deviation from these plans without the prior express, written approval of the agency. Any deviations from these plans or the above conditions may lead to such sanctions and penalties as provided for under Ohio law. Approval of this plan and issuance of this permit does not constitute an assurance by the Ohio Environmental Protection Agency that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed sources are inadequate or cannot meet applicable standards.

This permit to install applies only to the wastewater treatment works listed above. The installation of drinking water supplies, air contaminant sources, or solid waste disposal facilities will require the submittal of a separate application to the director.

Roof drains, foundation drains, and other clean water connections to the sanitary sewer shall be prohibited by enforcement of legally adopted rules by the authority regulating the use of sanitary sewers.

Sewer and manhole construction joints shall conform to standards of the Ohio Environmental Protection Agency.