

# W. E. OLSON Electric Inc.

ELECTRICAL CONTRACTORS

Phone (419) 784-4700



P.O. BOX 332 - - DEFIANCE, OHIO 43512

March 28, 1980

City of Napoleon, Ohio  
255 Riverview Avenue  
Napoleon, Ohio 43545

Attn: Norman Howes, Electrical Inspector

Re: Correction Notice - River City Recreation

Gentlemen:

Per your letter of March 24, 1980 - have checked this matter out and found that we are in compliance.

Our emergency circuits and our lighting raceways are not in violation.

Emergency circuits are in separate conduit.

Sincerely yours,

W. E. OLSON ELECTRIC INC.

President

WEO/ed



**CITY OF NAPOLEON**  
**Engineering Department**  
 255 Riverview Avenue  
 NAPOLEON, OHIO 43545

DATE 4-5-80		JOB NO.	
PROJECT			
LOCATION			
CONTRACTOR		OWNER	
WEATHER		TEMP. ° at	AM
		° at	PM
PRESENT AT SITE			

TO \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

THE FOLLOWING WAS NOTED:

> Bruce -

I received a phone call from Olsen Elect (Def) relative to our letter concerning Emergency wiring at the new Bowling Alley, stating that our source of information was not accurate.

I talked to the journeyman wiseman that was on the job & asked him to verify this in writing, and send to nap. City hall, my attention, if he does this it will satisfy me that he's right. If Mr Meyers is not satisfied, ask him to prove his point with a photograph of the violation.

VHy

W.H.

COPIES TO \_\_\_\_\_

**FIELD REPORT**

SIGNED \_\_\_\_\_



**CITY OF NAPOLEON**  
**Engineering Department**  
 255 Riverview Avenue  
 NAPOLEON, OHIO 43545

DATE		JOB NO.	
PROJECT			
LOCATION			
CONTRACTOR		OWNER	
WEATHER		TEMP.	° at AM
		° at	PM
PRESENT AT SITE			

TO \_\_\_\_\_

THE FOLLOWING WAS NOTED:

Please write letter to

3-22-80

Olsen Elec Co  
 Defiance Ohio

Re: Correction notice; Bowling Alley  
 Independence Rd. Nap, Ohio

It has been called to our attention that normal circuitry & Emergency circuitry are run in the same raceway; Lighting over lane #1, west side of Blfy. This method is not in compliance with Article 700-17-1978 NEC.

Please notify <sup>Bldg & zoning Dept - City of Napoleon</sup> within ten (10) days after receipt of this notice that the work has been corrected.

Failure to comply with this request may result in discontinuation of service.

Vfy

**FIELD REPORT**

COPIES TO \_\_\_\_\_

SIGNED \_\_\_\_\_

N. Howes  
 Elec Dept  
 City of Nap

