



# City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE — (419) 592-4010

February 10, 1981

**Mayor**  
Robert G. Heft

Mr. Tony Hoeffel  
Mel Lanzer Co.  
2266 Scott St.  
Napoleon, OH 43545

**Clerk-Treasurer**  
Rupert W. Schweinhagen

Re: Exit lights for theatres

**Members of Council**  
Lawrence Haase, President  
James Jackson  
William Young  
Darel Austermler  
Darrell Fox  
James Zumfelde

Dear Tony:

Please find enclosed your approved drawings of the electrical layout for exit lights for the theatres.

Please note that the southeast exit at the north theatre is to have a sign reading "Emergency Exit Only" on the door.

**City Manager**  
Alan E. Tandy

If you have any questions, or need anything, just call.

**Law Director**  
Keith P. Muehlfeld

Yours truly,

Richard G. Hayman  
Building Commissioner

RGH:dd

Enc.

THEATER  
RGH

# City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE — (419) 592-4010

February 5, 1981



**Mayor**

Robert G. Heft

Mr. Tony Hoeffel  
Mel Lanzer Company  
2266 N. Scott St.  
Napoleon, OH 43545

**Clerk-Treasurer**

Rupert W. Schweinhagen

Dear Tony:

**Members of Council**

Lawrence Haase, President  
James Jackson  
William Young  
Darel Austermilller  
Darrell Fox  
James Zumfelde

In reference to your note of February 4, 1981, I discussed the sign with John Fruchey and we feel that a sign stating "No Exit" would be sufficient. This could be in one line or two. If it was in one line, "No" would be on one door and "Exit" on the other. If it's in two lines, one above the other, a sign would have to be placed on each door.

**City Manager**

Alan E. Tandy

I hope this solves your problem.

Yours truly,

**Law Director**

Keith P. Muehlfeld

Richard G. Hayman  
Building Commissioner

RGH:dd