


# Certificate of Occupancy

## Wood County Building Inspection

<p><b>Address:</b>  <b>KID'S HAVEN PRESCHOOL &amp; DAYCARE</b>  <b>CENTER</b>          440 INDEPENDENCE DRIVE          NAPOLEON, OH 43545          County: Henry</p>	<p><b>Stipulations, Conditions, &amp; Variances:</b>  <b>Health &amp; Safety Only.</b>  <b>Maximum Occupancy is 178, with a limited number of 30 Children less than 2 1/2 of age located in a area/room having direct access/exiting to the exterior of the Building.</b>  <b>Note: The existing kitchen area is not approved for the preparation of food, (cooking is prohibited and remove all existing appicances and cap off all gas lines.</b></p>												
<p><b>Approved As:</b></p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;">Use Groups:</th> <th style="width: 70%;">Occupancy Description:</th> </tr> </thead> <tbody> <tr> <td>Primary</td> <td>E Day Care / Pre-School</td> </tr> <tr> <td>Accessory</td> <td>0</td> </tr> <tr> <td>Accessory</td> <td>0</td> </tr> <tr> <td>Accessory</td> <td>0</td> </tr> <tr> <td>Mixed Use</td> <td>0</td> </tr> </tbody> </table> <p>Attached Floor Plan: <input type="checkbox"/></p>	Use Groups:	Occupancy Description:	Primary	E Day Care / Pre-School	Accessory	0	Accessory	0	Accessory	0	Mixed Use	0	<p>This Certificate represents an approval that is valid only when the building and its facilities are used as stated and is conditional upon all building systems being maintained and tested in accordance with the applicable Ohio Board of Building Standards rules and applicable equipment or systems schedules. This certifies conformance with Chapters 3781 and 3791 of the Ohio Revised Code and the applicable provisions of the rules of the Ohio Board of Building Standards.</p>
Use Groups:	Occupancy Description:												
Primary	E Day Care / Pre-School												
Accessory	0												
Accessory	0												
Accessory	0												
Mixed Use	0												
<p><b>Construction Type:</b> 2B <b>Sprinklers</b></p>	<p><b>System Type:</b> NFPA 13 <b>Demand:</b></p> <p><b>Standpipe:</b></p> <p><b>Location:</b> Partial</p>												
<p><b>Specific Hazards:</b> Note: All Fire Sprinklers and Fire Alarm Systems are required to be monitored, tested, and certified annually for this Occupancy Approval to remain valid.</p>													
<p><b>OB Ed. 2017</b>   <b>OMC Ed. 2017</b>   <b>OPC Ed. 2017</b></p> <p><b>Health and Safety OBC Section 111.1</b></p> <p><b>Plan Approval/Building Permit No: C18-000473</b></p> <p><b>Date:</b> 08/27/2019</p> <p><b>Chief Building Official:</b>           Michael J. Rudey</p>													