

CITY OF NAPOLEON
ENGINEERING DEPARTMENT

SIGN PERMIT

(Please Print or Type)

Do Not Write Within Boxed Area.
For Engineering Office Use Only.

Permit No.	069
Issued	5-18-81
By	R. J. Hummer
Estimated Cost	\$838.00
Base Fee	4.00
Add	3.50
Total Fee	\$7.50

WHEELS & WHEELS INC.

INDEPENDENCE

Address 204 W. ELM WILMINGTON OH Tel. 335-7741

BILLBOARD

AWNING

MARQUEE

PAID

MAY 18 1981

CITY OF NAPOLEON
Square Feet

Signature of Applicant

Application Must Be Accompanied with Sketch and Description of Proposed Installation
Yellow - Clerk-Treasurer
Pink - Engineering
Gold - County Auditor

470 INDEPENDENCE

PLASTIC INDU. LETTERS

28'



City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE — (419) 592-4010

January 21, 1981

Mayor
Robert G. Heft

Mel Lanzer Company
2266 N. Scott St.
Napoleon, Oh. 43545
Att: Tony Hoeffel

Clerk-Treasurer
Rupert W. Schweinhagen

RE: Review of meeting.

Members of Council
Lawrence Haase, President
James Jackson
William Young
Darel Austermilller
Darrell Fox
James Zumfelde

Dear Mr. Hoeffel:

This is a review of the decisions and approvals given at the meeting of January 19, 1981 at the new cinema building on Independence Drive.

South Theater

City Manager
Alan E. Tandy

1. One exit light at each exit stairs at screen end of theater shall be placed on wall extending outward from wall at top of stairs on theater seating side of curtain on stair landing.
2. Center entrance door into theater shall not be required to have an exit light but shall be required to have a sign on both sides of door reading "Entrance Only" in six (6) inch letters in height and legible from both inside and outside.
3. One theater isle exit light shall be installed on ceiling edge at rear of theater over isle way on each side of theater. These lights shall be directional to the west of the theater.
4. One exit light shall be installed over rear west exit door at the rear of the theater. The battery pack of this light shall extend through the suspended ceiling over the exit door.

Law Director
Keith Muehlfeld

North Theater

1. This theater shall be the same as the south theater except the office and projection room exterior door shall have an exit light over the exterior door.
2. The door leading from the theater to the projection room shall have a sign reading "Emergency Only" in six (6) inch high letters that are legible.

South Office

1. One exit light shall be installed over the west interior door leading into the vestibule to the exterior. (No exit light would be required over vestibule exit door.)
2. One exit light shall be installed over exit door leading into theater lobby.
3. One exit light shall be installed over exit door on office side leading to waiting and reception room.

North Office

1. Exit lights shall be installed the same as 1 and 2 of the South office.
2. If more partitions are installed in either of these two offices, the Building Commissioners and Fire Inspector shall be notified and exit lights shall be installed if necessary.

Theater Lobby


1. One exit light shall be installed over north and south exit door in lobby.
2. No exit light shall be required over center lobby entrance doors.

Mr. Tony Hoeffel

Pg. 3.

Any changes in the drawings that were approved by the building department to obtain permits shall be approved by the Building Commissioner and have a drawing change submitted for approval prior to the change.

Very truly yours,



Richard G. Hayman
Building Commissioner

RGH/bk