

PUNCH LIST NO 1
D, W, E, S CREW

- ✓1 CAULK WEST WINDOW ON NORTH ELEV.
- ✓2 CAULK STAIN LINES & WALL ON ALL EXTREME DOORS & WINDOWS
- ✓3 2- 4'-0" GOARD POSTS TO BE INSTALLED AT THE TRANSFORMER
1- 2'-6" PRESTRESS INSTALLED
- ✓4 REPAIR DASH TO WOMAN'S TOILET AND 1-OFFICE
- ✓5 REPAIR 1- EXHAUST FAN GRILL IN OFFICE TOILET & CHECK OTHER EX FAN FOR PROPER OPERATION
- ✓6 INSTALL OFFICE DOOR STOPS
- ✓7 TIGHTEN X-BRACING CAPS ON RIGID FRAME
- ✓8 PAINT DUCTWORK TO MATCH THE METAL SIDING AROUND THE CONC BUC,
- ✓9 CAULK AROUND DOCTS YARD WALL
- ✓10 PATCH PAINT ON EXTERIOR OR BLOCK
- ✓11 POOR A CONC STOOP AT THE OFFICE WEST EXTERIOR DOOR

✓ 13

PATCH THE WALL AT THE
FLOOR LINE NEXT TO THE PCWP
TO OFFICE DOOR

✓ 14

ADJUST TWO DOORS 1- PLANT ROOM
TOILET & 1- OFFICE DOOR

15

BOTTOM OF METAL SIDING TO STEEL
RUNNER NOT A WEAT CONNECTION