

Michael J. Billmaier
Chief Building Inspector
Phone (419) 354-9190
Fax (419) 354-2904 or
(419) 354-1409



County Office Building
One Courthouse Square
Bowling Green, OH 43402
<http://www.wcnet.org/~inspect>
E-Mail: inspect@wcnet.org

BUILDING INSPECTION

Date: May 11, 2000

Job No. 40804
Job Name: Leader Engineering
Applicant: Owner
Address: 695 Independence Dr.
Twp./Corp. Napoleon Corp.
Reviewed by: Robert Connelly

CORRECTIONS: (No Permit Issued)

Note! Per Section 4101: 2-1-23 of the Ohio Basic Building Code, the documents as submitted for the above referenced project have been reviewed and found to be either inadequate or in non-compliance with the Ohio Basic Building Code. The submitter shall review the following corrections, make appropriate revisions/additions to the documents and re-submit for review and approval.

Corrections:

1. Provide industrialized unit stamped drawings per OBBC.
2. Note minimum unit fire separation is 10 feet per drawing "field notes".

PAY-IN ORDER

CITY OF NAPOLEON

№ 9029

4-28, 1988

Received of Vernon Nagel Inc

PAY TO THE TREASURER OF SAID CITY

Sixty and 00/100 DOLLARS, \$ 60.00

For Sewer Tap

which amount is to be placed to the credit of _____ Fund

R. W. Schweinhagen
CLERK-TREASURER

INVOICE	AMOUNT
<u>Sewer Tap</u>	
<u>Permit</u>	
<u>Leadus</u>	

VERNON NAGEL, INC.
GENERAL CONTRACTOR
0-154 RD. 11-C, ROUTE #5
PHONE 419-592-3861
NAPOLEON, OHIO 43545

№ 20908

56-14
412

OHIO CITIZENS BANK
TOLEDO, OHIO 43603-1688

VOID AFTER 30 DAYS

PAY VERNON NAGEL INC. 60 DOLS 00 CTS DOLLARS

DATE	TO THE ORDER OF	GROSS	DISCOUNT	ALLOWANCE	NET AMOUNT OF CHECK	CHECK NO.
<u>4/28/88</u>	<u>City of Napoleon</u>				<u>60.00</u>	<u>20908</u>

VERNON NAGEL, INC.

Jerry Nagel


⑈020908⑈ ⑆041200144⑆ 24 00707⑈

90

Independence Drive

M.H.
Existing 12" P.V.C. 240.5 Ft.

TAP To downstream M.H.



4.0 depth

450 bend

Below Footer @ bldg.