

City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE - (419) 592-4010
NAPOLEON, OHIO 43545-0151



February 8, 1994

Mayor
Robert G. Heft

Mr. Don Wichman
Fire Tech Sprinkling Inc.
4248 Kingsmoor Dr.
Toledo, Ohio 43613

Members of Council
John E. Church, President
Michael J. DeWit
James Hershberger
Sarah Peper
Terri A. Williams
Travis B. Sheaffer
Charles E. Burgoon

Re. Arrow Molded Plastics Expansion
800 Independence, Napoleon.

Dear Mr. Wichman

City Manager
Terry Dunn

The 8" Ames 2000 DCA backflow device proposed for the fire protection system for job no. 94-001 is hereby approved as drawn. Please notify me upon installation completion so I may inspect the assembly.

Finance Director
Rupert W. Schweinhagen

The City of Napoleon requires an annual testing of backflow devices by a State of Ohio certified person/firm, to insure proper function. Please forward annual test reports to Brent N. Damman, City of Napoleon Engineering Dept. 255 W. Riverview Napoleon Ohio.

Law Director
David M. Grahn

For inspection and/or questions please call me at 592-4010. between 8:00 a.m. & 5:00 p.m. Monday thru Friday.

City Engineer
Marc S. Gerken

Sincerely

Brent N Damman
Building & Zoning Adm.
Backflow Program Adm.

cc. Marc S. Gerken, City Engineer



FIRE TECH SPRINKLER, INC.
Design, Installation & Maintenance of Sprinkler Systems

4248 Kingsmoor
Toledo, Ohio 43613
(419) 472-4697

LETTER OF TRANSMITTAL

TO CITY OF NAPOLEON
255 Riverview Ave.
Napoleon, Ohio 43545

DATE <u>1-12-94</u>	JOB NO. <u>94-001</u>
ATTENTION <u>Marc Gerkin</u>	
RE: <u>ARROW MOLDED PLASTICE</u>	
<u>Independence Dr.</u>	
<u>Napoleon, Ohio</u>	

WE ARE SENDING YOU Attached Under separate cover via _____ the following items:

- Shop drawings Prints Plans Samples Specifications
 Copy of letter Change order _____

COPIES	DATE	NO.	DESCRIPTION
2			Fire Protection sprinkler drawings for your review
2			Hydraulic Calculations

THESE ARE TRANSMITTED as checked below:

- For approval Approved as submitted Resubmit _____ copies for approval
 For your use Approved as noted Submit _____ copies for distribution
 As requested Returned for corrections Return _____ corrected prints
 For review and comment _____
 FOR BIDS DUE _____ 19 _____ PRINTS RETURNED AFTER LOAN TO US

REMARKS Marc: We are sending these plans for your review. Should you have any
questions, changes or additions please don't hesitate to call and we will try
our best to answer them. Thank you,

COPY TO R & R THREE

SIGNED: Don Wichman

Hydraulic Design Information Sheet

Name: ARROW MOLDED PLASTICS, INC. Date: 01/12/1994 System No.: TWO
Location: INDUSTRIAL/INDEPENDENCE DRIVES NAPOLEON OH. 43545
Contractor: FIRE TECH SPRINKLER, INC. Telephone: 419-472-4697
4248 KINGSMOOR DRIVE TOLEDO OH. 43613
Calculated By: D.HAYES G-085 Contract No.:
Construction: NON-COMBUSTIBLE Drawing No.: FP-2 of 3
Occupancy: MFG. & WAREHOUSE Ceiling Height: 29'-0"

System Design

Code: NFPA #13 1991 Review Agency: OWNERS INSURANCE CO.

Area of Sprinkler Operation: 2000		System Type: WET/GRID
Density (gpm/sq.ft.): .45		
Area Per Sprinkler: 83.450.FT.		Sprinkler or Nozzle
Hose Allowance gpm Inside: 100		Make: ASCOA Model: "G"
Hose Allowance gpm Outside: 400		Size: 17/32" K-factor: 8.1
Rack Sprinkler Allowance: NA		Temperature Rating: 280/F

Calculation Summary

Requires 1410.5 gpm at 48.72 psi at CONNECTION TO CITY MAIN
Interior C-factor: 120 Underground C-factor: 150

Water Supply Test Information		Pump Data		Tank Data
Test by: ARCHITECT				
Date: 11/22/89		Type: N/A		Elevation: N/A
Time:		Elevation: N/A		Size: N/A
Location: IN FRONT OF PROPERTY		Rated Psi: N/A		
Elevation: 1.5'		Rated Gpm: N/A		
Static Pressure: 64.0				
Residual Pressure: 56.0				
Flow: 1396		Well Proof Flow: N/A		

Storage Details:

Commodity: N/A	Class: N/A
Location: NA	Storage Area: NA
Storage Height: NA	Clearance to Ceiling: NA
Single, Double, or Multi Row: NA	Aisle Width: NA
Pallet Type: NA	Encapsulated?: NA
Storage Method: %Solid Piled: NA	%Palletized: NA %Rack: NA
Longitudinal Flue Spacing: NA	Transverse Flue Spacing: NA
Horiz. Barriers Provided?: NA	

Donald W. Hayes
G-085

=====

=====

S U M M A R Y

O F

H Y D R A U L I C

C A L C U L A T I O N S

F O R

ARROW MOLDED PLASTICS, INC.

INDUSTRIAL/INDEPENDENCE DRIVES NAPOLEON OH. 43545 Job No:

=====

Submitted By

FIRE TECH SPRINKLER, INC. 4248 KINGSMOOR DRIVE TOLEDO OH. 43613

=====

Design Specifications	Water Supply Information	System Demand
Density : 0.450	64.00 psi @ 0.00 gpm	48.72 psi
Design Area: 2000.00	56.00 psi @ 1396.00 gpm	@
		1010.5 gpm
		+ 400.0 gpm Hose
		Total Demand: 1410.5 gpm @ 48.72 psi
		System safety factor: 7.11 psi

Notes:

List of Fitting Abbreviations

Example: "E2TC" = one Std. Elbow, two Std. Tee , and one Check Va

Code:Description	Code:Description	Code:Description	Code:Description
A : Alarm Va	H :	O :	V :
B : Butt flyVa	I :	P :	W :
C : Check Va	J :	Q :	X :
D : DryPipeVa	K :	R :	Y :
E : Std. Elbow	L : LongTurnEl	S :	Z :
F : 45 Ell	M : Deluge Va.	T : Std. Tee	
G : Gate Va	N :	U :	

Summary of Sprinkler and Hose Flows

Job No:

ARROW MOLDED PLASTICS, INC.

Design density: .45

Supplied flow and pressure is based on 48.72 psi available at supply
 (55.85 psi is actually available)

Ref. Pt.	PRESSURE			K Factor	FLOW		Percent Excess	Ref. Pt.
	Pt	Pv	Pn		Actual	Minimum		
M01	45.28		45.28	0.00	100.0	100.0	0.0%	M01
S01	22.42		22.42	8.10	38.4	37.5	2.4%	S01
S02	21.90		21.90	8.10	37.9	37.5	1.1%	S02
S03	21.65		21.65	8.10	37.7	37.5	0.5%	S03
S04	21.47		21.47	8.10	37.5	37.5	0.0%	S04
S05	21.62		21.62	8.10	37.7	37.5	0.5%	S05
S06	22.25		22.25	8.10	38.2	37.5	1.9%	S06
S07	22.44		22.44	8.10	38.4	37.5	2.4%	S07
S08	21.92		21.92	8.10	37.9	37.5	1.1%	S08
S09	21.66		21.66	8.10	37.7	37.5	0.5%	S09
S10	21.48		21.48	8.10	37.5	37.5	0.0%	S10
S11	21.63		21.63	8.10	37.7	37.5	0.5%	S11
S12	22.26		22.26	8.10	38.2	37.5	1.9%	S12
S13	22.49		22.49	8.10	38.4	37.5	2.4%	S13
S14	21.97		21.97	8.10	38.0	37.5	1.3%	S14
S15	21.71		21.71	8.10	37.7	37.5	0.5%	S15
S16	21.53		21.53	8.10	37.6	37.5	0.3%	S16
S17	21.67		21.67	8.10	37.7	37.5	0.5%	S17
S18	22.31		22.31	8.10	38.3	37.5	2.1%	S18
S19	22.61		22.61	8.10	38.5	37.5	2.7%	S19
S20	22.07		22.07	8.10	38.0	37.5	1.3%	S20
S21	21.81		21.81	8.10	37.8	37.5	0.8%	S21
S22	21.63		21.63	8.10	37.7	37.5	0.5%	S22
S23	21.77		21.77	8.10	37.8	37.5	0.8%	S23
S24	22.40		22.40	8.10	38.3	37.5	2.1%	S24

Path No: 1 Remote to Supply

Principal path

Feeds Path:2 at Pt:A02, Path:3 at Pt:A03, Path:4 at Pt:A04, Path:5 at Pt:A16

Ref Pt.	Elev. ft.	Pressure (psi) Pt	Pv	K Pn	Flow (gpm) Added	Veloc (fps)	Diam. in.	Actual Length	Fitting Summary	Fitting Length	Total Length	Frict. Loss per.ft	Elev. Loss (ft.)	Next Ref Press Pt.
(C=120)														
C01	22.50	29.29				9.37	2.157	2.00	T	10.00	12.00	0.087	-1.04	D01
D01	24.50	27.39				8.79	2.227	45.25	T	10.00	55.25	0.074	-4.09	S01
S01	26.51	22.42	8.10	38.4	-68.6	5.64	2.227	10.00		10.00	0.033	-0.33	-0.18	S02
S02	26.93	21.90	8.10	37.9	-30.7	2.53	2.227	10.00		10.00	0.007	-0.07	-0.18	S03
S03	27.35	21.65	8.10	37.7	6.9	0.57	2.227	10.00		10.00	0.000	0.00	-0.18	S04
S04	27.77	21.47	8.10	37.5	44.5	3.65	2.227	10.00		10.00	0.015	0.15		S05
S05	27.77	21.62	8.10	37.7	82.1	6.75	2.227	10.00		10.00	0.045	0.45	0.18	S06
S06	27.35	22.25	8.10	38.2	120.3	9.88	2.227	65.25	T	10.00	75.25	0.092	6.92	B01
B01	24.50	30.42				10.54	2.157	2.00	T	10.00	12.00	0.108	1.29	A01
A01	22.50	32.57				1.21	6.357	8.34			8.34	0.001	0.00	A02
A02	22.50	32.58		120.3	240.6	2.43	6.357	8.34			8.34	0.002	0.02	A03
A03	22.50	32.59		120.1	360.7	3.64	6.357	8.34			8.34	0.004	0.04	A04
A04	22.50	32.63		119.6	480.3	4.84	6.357	8.34			8.34	0.007	0.06	A05
A05	22.50	32.69		41.9	522.2	5.26	6.357	8.34			8.34	0.008	0.07	A06
A06	22.50	32.76		39.9	562.1	5.67	6.357	8.34			8.34	0.010	0.08	A07
A07	22.50	32.84		38.4	600.5	6.05	6.357	8.34			8.34	0.011	0.09	A08
A08	22.50	32.93		37.3	637.8	6.43	6.357	8.34			8.34	0.012	0.10	A09
A09	22.50	33.03		36.7	674.5	6.80	6.357	8.34			8.34	0.014	0.11	A10
A10	22.50	33.15		36.5	711.0	7.17	6.357	8.34			8.34	0.015	0.12	A11
A11	22.50	33.27		36.7	747.7	7.54	6.357	8.34			8.34	0.016	0.14	A12
A12	22.50	33.41		37.3	785.0	7.91	6.357	8.34			8.34	0.018	0.15	A13
A13	22.50	33.56		38.3	823.3	8.30	6.357	4.21	T	30.00	34.21	0.020	0.67	A16
A16	22.50	34.22		87.3	910.5	9.18	6.357	39.00	AB2L	53.00	92.00	0.024	2.16	M01
M01	2.00	45.28		100.0	1010.5	6.32	8.071	6.00	4C2BL	201.00	207.00	0.009	1.85	M02
(C=150)														
M02	1.00	47.56			1010.5	6.26	8.110	160.00	GLT	78.58	238.58	0.006	1.38	M03
M03	1.50	48.72			AAAAA									

B.D.R.

Path No: 2 Grid Line

Fed by path No.1

Ref Pt.	Elev. ft.	Pressure (psi) Pt	Pv	K Pn	Flow (gpm) Added	Veloc (fps)	Diam. in.	Actual Length	Fitting Summary	Fitting Length	Total Length	Frict. Loss per.ft	Elev. Loss (ft.)	Next Ref Press Pt.
(C=120)														
C02	22.50	29.32				9.38	2.157	2.00	T	10.00	12.00	0.087	-1.04	D02
D02	24.50	27.41				8.80	2.227	45.25	T	10.00	55.25	0.074	-4.10	S07
S07	26.51	22.44	8.10	38.4	-68.8	5.65	2.227	10.00		10.00	0.033	-0.33	-0.18	S08
S08	26.93	21.92	8.10	37.9	-30.8	2.53	2.227	10.00		10.00	0.007	-0.07	-0.18	S09
S09	27.35	21.66	8.10	37.7	6.9	0.56	2.227	10.00		10.00	0.000	0.00	-0.18	S10
S10	27.77	21.48	8.10	37.5	44.4	3.65	2.227	10.00		10.00	0.015	0.15		S11
S11	27.77	21.63	8.10	37.7	82.1	6.74	2.227	10.00		10.00	0.045	0.45	0.18	S12
S12	27.35	22.26	8.10	38.2	120.3	9.88	2.227	65.25	T	10.00	75.25	0.092	6.92	B02
B02	24.50	30.42				10.53	2.157	2.00	T	10.00	12.00	0.107	1.29	A02
A02	22.50	32.58												

Path No: 3 Grid Line

Fed by path No.1

Ref Pt.	Elev. ft.	Pressure (psi) Pt	Pv	K Pn	Flow (gpm) Added	Veloc (fps)	Diam. (in.)	Actual Length	Fitting Summary	Fitting Length	Total Length	Frict. Loss per.ft	Elev. Loss Total	Next Ref Press Pt.	
(C=120)															
D03	22.50	29.42			-107.6	9.42	2.157	2.00	T	10.00	12.00	0.087	-1.05	-0.87 (-2.00)	27.50 D03
D03	24.50	27.50			-107.6	8.84	2.227	45.25	T	10.00	55.25	0.075	-4.13	-0.87 (-2.01)	22.49 S13
S13	26.51	22.49	8.10	38.4	-69.2	5.68	2.227	10.00		10.00	0.033	-0.33	-0.18 (-0.42)	21.97 S14	
S14	26.93	21.97	8.10	38.0	-31.2	2.56	2.227	10.00		10.00	0.008	-0.08	-0.18 (-0.42)	21.71 S15	
S15	27.35	21.71	8.10	37.7	6.5	0.54	2.227	10.00		10.00	0.000	0.00	-0.18 (-0.42)	21.53 S16	
S16	27.77	21.53	8.10	37.6	44.1	3.62	2.227	10.00		10.00	0.014	0.14		21.67 S17	
S17	27.77	21.67	8.10	37.7	81.8	6.72	2.227	10.00		10.00	0.045	0.45	0.18 (0.42)	22.31 S18	
S18	27.35	22.31	8.10	38.3	120.1	9.86	2.227	65.25	T	10.00	75.25	0.092	6.90	1.24 (2.85)	30.44 B03
B03	24.50	30.44			120.1	10.51	2.157	2.00	T	10.00	12.00	0.107	1.29	0.87 (2.00)	32.59 A03
A03	22.50	32.59			*****										

Path No: 4 Grid Line

Fed by path No.1

Ref Pt.	Elev. ft.	Pressure (psi) Pt	Pv	K Pn	Flow (gpm) Added	Veloc (fps)	Diam. (in.)	Actual Length	Fitting Summary	Fitting Length	Total Length	Frict. Loss per.ft	Elev. Loss Total	Next Ref Press Pt.	
(C=120)															
D04	22.50	29.62			-108.5	9.50	2.157	2.00	T	10.00	12.00	0.089	-1.07	-0.87 (-2.00)	27.68 D04
D04	24.50	27.68			-108.5	8.92	2.227	45.25	T	10.00	55.25	0.076	-4.20	-0.87 (-2.01)	22.61 S19
S19	26.51	22.61	8.10	38.5	-70.0	5.75	2.227	10.00		10.00	0.034	-0.34	-0.18 (-0.42)	22.07 S20	
S20	26.93	22.07	8.10	38.0	-32.0	2.63	2.227	10.00		10.00	0.008	-0.08	-0.18 (-0.42)	21.81 S21	
S21	27.35	21.81	8.10	37.8	5.8	0.48	2.227	10.00		10.00	0.000	0.00	-0.18 (-0.42)	21.63 S22	
S22	27.77	21.63	8.10	37.7	43.5	3.57	2.227	10.00		10.00	0.014	0.14		21.77 S23	
S23	27.77	21.77	8.10	37.8	81.3	6.68	2.227	10.00		10.00	0.045	0.45	0.18 (0.42)	22.40 S24	
S24	27.35	22.40	8.10	38.3	119.6	9.83	2.227	65.25	T	10.00	75.25	0.091	6.85	1.24 (2.85)	30.49 B04
B04	24.50	30.49			119.6	10.48	2.157	2.00	T	10.00	12.00	0.106	1.28	0.87 (2.00)	32.63 A04
A04	22.50	32.63			*****										

Path No: 5 Far Main


Fed by path No.1

Ref Pt.	Elev. ft.	Pressure (psi) Pt	Pv	K Pn	Flow (gpm) Added	Veloc (fps)	Diam. (in.)	Actual Length	Fitting Summary	Fitting Length	Total Length	Frict. Loss per.ft	Elev. Loss Total	Next Ref Press Pt.
(C=120)														
C01	22.50	29.29			107.0	2.40	4.260	8.34			8.34	0.003	0.03	29.32 C02
C02	22.50	29.32			107.1	2.14	4.260	8.34			8.34	0.011	0.09	29.42 C03
C03	22.50	29.42			107.6	3.21	4.260	8.34			8.34	0.024	0.20	29.62 C04
C04	22.50	29.62			108.5	4.30	4.260	8.34			8.34	0.041	0.34	29.96 C05
C05	22.50	29.96			-41.9	3.88	4.260	8.34			8.34	0.034	0.28	30.27 C06
C06	22.50	30.27			-39.9	3.48	4.260	8.34			8.34	0.028	0.23	30.52 C07
C07	22.50	30.52			-38.4	3.10	4.260	8.34			8.34	0.023	0.19	30.73 C08

Path No: 5 (Continued) Far Main

Fed by path No.1

Ref Pt.	Elev. ft.	Pressure (psi) Pt	Pressure (psi) Pv	K Pn	Flow (gpm) Total	Flow (gpm) Added	Veloc (fps)	Diam. in.	Actual Length	Fitting Summary Length	Fitting Length	Total Length	Frict. Loss per.ft	Loss Total	Elev. Loss (ft.)	Next Press Pt.	Ref Pt.
(C=120)																	
C08	22.50	30.73	30.73		-37.3	272.7	6.12	4.260	8.34			8.34	0.018	0.15		30.90	C09
C09	22.50	30.90	30.90		-36.7	236.1	5.30	4.260	8.34			8.34	0.014	0.11		31.04	C10
C10	22.50	31.04	31.04		-36.5	199.6	4.48	4.260	8.34			8.34	0.010	0.08		31.14	C11
C11	22.50	31.14	31.14		-36.7	162.9	3.66	4.260	8.34			8.34	0.007	0.06		31.20	C12
C12	22.50	31.20	31.20		-37.3	125.6	2.82	4.260	8.34			8.34	0.004	0.04		31.25	C13
C13	22.50	31.25	31.25		-38.3	87.3	1.96	4.260	8.34			8.34	0.002	0.02		31.27	C14
C14	22.50	31.27	31.27		-43.7	43.6	0.98	4.260	8.34			8.34	0.001	0.00		31.27	C15
C15	22.50	31.27	31.27			43.6	3.82	2.157	2.00	T	10.00	12.00	0.016	0.20	-0.87 (-2.00)	30.61	D15
D15	24.50	30.61	30.61			43.6	3.58	2.227	160.50	TT	20.00	180.50	0.014	2.54		33.15	B15
B15	24.50	33.15	33.15			43.6	3.82	2.157	2.00	T	10.00	12.00	0.016	0.20	0.87 (2.00)	34.21	A15
A15	22.50	34.21	34.21			43.6	0.44	6.357	8.34			8.34	0.000	0.00		34.21	A14
A14	22.50	34.21	34.21		43.7	87.3	0.88	6.357	4.21	T	30.00	34.21	0.000	0.01		34.22	A16
A16	22.50	34.22	34.22			*****											



Pressure vs. Flow
 64.00 0.00
 56.00 1396.00
 0 4295.76

ARROW MOLDED PLASTICS, INC.
 INDUSTRIAL/INDEPENDENCE DRIVES
 NAPOLEON OH. 43545

Job Number :
 01/12/1994

Diet

Flow Diagram for ARROW MOLDED PLASTICS, INC.



Handwritten signature or initials

Hydraulic Design Information Sheet

Name: ARROW MOLDED PLASTICS Date: 01/12/1994 System No.: ONE
Location: INDUSTRIAL DRIVE NAPOLEON OH, 43545
Contractor: FIRE TECH SPRINKLER, INC. Telephone: 419-472-4697
4248 KINGSMOOR DRIVE TOLEDO OH, 43613
Calculated By: D. HAYES G-085 Contract No.:
Construction: Non-Combustible Drawing No.: FP-3 of 3
Occupancy: MFG. & WAREHOUSE Ceiling Height: 29'-0"

System Design

Code: NFPA #13 1991 Review Agency: OWNERS INSURANCE CO.

Area of Sprinkler Operation: 2000		System Type: WET/GRID
Density (gpm/sq.ft.): .45		
Area Per Sprinkler: 83.4 Max.		Sprinkler or Nozzle
Hose Allowance gpm Inside: 100		Make: ASCOA Model: "G"
Hose Allowance gpm Outside: 400		Size: 17/32" K-factor: 8.1
Rack Sprinkler Allowance: N/A		Temperature Rating: 280/F

Calculation Summary

Requires 1410.5 gpm at 50.20 psi at CONNECTION TO CITY WATER MAIN
Interior C-factor: 120 Underground C-factor: 150

Water Supply Test Information		Pump Data		Tank Data
Test by: ARCHITECT				
Date: 11/22/89		Type: N/A		Elevation: N/A
Time:		Elevation: N/A		Size: N/A
Location: IN FRONT OF RISK PROPERTY		Rated Psi: N/A		
Elevation: 1.5'		Rated Gpm: N/A		
Static Pressure: 64				
Residual Pressure: 56				
Flow: 1396		Well Proof Flow: N/A		

Storage Details:

Commodity: N/A	Class: N/A
Location: N/A	Storage Area: N/A
Storage Height: N/A	Clearance to Ceiling: N/A
Single, Double, or Multi Row: N/A	Aisle Width: N/A
Pallet Type: N/A	Encapsulated?: N/A
Storage Method: %Solid Piled: N/A	%Palletized: N/A
	%Rack: N/A
Longitudinal Flue Spacing: N/A	Transverse Flue Spacing: N/A
Horiz. Barriers Provided?: N/A	

Donald W. Hayes
G-085

=====

S U M M A R Y
O F
H Y D R A U L I C
C A L C U L A T I O N S
F O R
A R R O W M O L D E D P L A S T I C S

INDUSTRIAL DRIVE NAPOLEON OH. 43545 Job No:

=====

Submitted By
FIRE TECH SPRINKLER, INC. 4248 KINGSMOOR DRIVE TOLEDO OH. 43613

Design Specifications	Water Supply Information	System Demand
Density : 0.450	64.00 psi @ 0.00 gpm	50.20 psi
Design Area: 2000.00	56.00 psi @ 1396.00 gpm	@ 1010.5 gpm
		+ 400.0 gpm Hose
		Total Demand: 1410.5 gpm @ 50.20 psi
		System safety factor: 5.63 psi

Notes: _____

List of Fitting Abbreviations

Example: "E2TC" = one Std. Elbow, two Std. Tee , and one Check Va

Code:Description	Code:Description	Code:Description	Code:Description
A : Alarm Va	H :	O :	V :
B : Butt flyVa	I :	P :	W :
C : Check Va	J :	Q :	X :
D : DryPipeVa	K :	R :	Y :
E : Std. Elbow	L : LongTurnEl	S :	Z :
F : 45 Ell	M :	T : Std. Tee	
G : Gate Va	N :	U :	

Summary of Sprinkler and Hose Flows

Job No:

ARROW MOLDED PLASTICS

Design density: .45

Supplied flow and pressure is based on 50.20 psi available at supply
 (55.85 psi is actually available)

Ref. Pt.	PRESSURE			K Factor	FLOW		Percent Excess	Ref. Pt.
	Pt	Pv	Pn		Actual	Minimum		
=====	=====	=====	=====	=====	=====	=====	=====	=====
M01	46.98		46.98	0.00	100.0	100.0	0.0%	M01
S01	22.42		22.42	8.10	38.4	37.5	2.4%	S01
S02	21.91		21.91	8.10	37.9	37.5	1.1%	S02
S03	21.65		21.65	8.10	37.7	37.5	0.5%	S03
S04	21.47		21.47	8.10	37.5	37.5	0.0%	S04
S05	21.62		21.62	8.10	37.7	37.5	0.5%	S05
S06	22.26		22.26	8.10	38.2	37.5	1.9%	S06
S07	22.44		22.44	8.10	38.4	37.5	2.4%	S07
S08	21.92		21.92	8.10	37.9	37.5	1.1%	S08
S09	21.66		21.66	8.10	37.7	37.5	0.5%	S09
S10	21.49		21.49	8.10	37.5	37.5	0.0%	S10
S11	21.63		21.63	8.10	37.7	37.5	0.5%	S11
S12	22.27		22.27	8.10	38.2	37.5	1.9%	S12
S13	22.49		22.49	8.10	38.4	37.5	2.4%	S13
S14	21.97		21.97	8.10	38.0	37.5	1.3%	S14
S15	21.71		21.71	8.10	37.7	37.5	0.5%	S15
S16	21.53		21.53	8.10	37.6	37.5	0.3%	S16
S17	21.68		21.68	8.10	37.7	37.5	0.5%	S17
S18	22.31		22.31	8.10	38.3	37.5	2.1%	S18
S19	22.61		22.61	8.10	38.5	37.5	2.7%	S19
S20	22.07		22.07	8.10	38.0	37.5	1.3%	S20
S21	21.81		21.81	8.10	37.8	37.5	0.8%	S21
S22	21.63		21.63	8.10	37.7	37.5	0.5%	S22
S23	21.77		21.77	8.10	37.8	37.5	0.8%	S23
S24	22.40		22.40	8.10	38.3	37.5	2.1%	S24

Path Summary Printout for ARROW MOLDED PLASTICS

Job No: 01/12/1994 System: ONE Drawing: FF-3 of 3

Path No: 1 Remote to Supply

Principal path

Feeds Path:2 at Pt:A02, Path:3 at Pt:A03, Path:4 at Pt:A04, Path:5 at Pt:A15

Ref Pt.	Elev. ft.	Pressure Pt	(psi) Pv	K Pn	Flow Factor	(gpm) Added	Veloc Total	Diam. fps	Actual in.	Fitting Length	Fitting Summary Length	Total Length	Frict.Loss per.ft	Elev. Loss Total	Next Ref Press Pt.
(C=120)															
C01	22.50	29.28	29.28			-106.9	9.36	2.157	2.00	T	10.00	12.00	0.086	-1.04	-0.87 (-2.00) 127.38 D01
D01	24.50	27.38	27.38			-106.9	8.78	2.227	45.25	T	10.00	55.25	0.074	-4.08	-0.87 (-2.01) 122.42 S01
S01	26.51	22.42	22.42	8.10	38.4	-68.5	5.63	2.227	10.00			10.00	0.032	-0.32	-0.18 (-0.42) 121.91 S02
S02	26.93	21.91	21.91	8.10	37.9	-30.6	2.51	2.227	10.00			10.00	0.007	-0.07	-0.18 (-0.42) 121.65 S03
S03	27.35	21.65	21.65	8.10	37.7	7.1	0.58	2.227	10.00			10.00	0.000	0.00	-0.18 (-0.42) 121.47 S04
S04	27.77	21.47	21.47	8.10	37.5	44.6	3.66	2.227	10.00			10.00	0.015	0.15	21.62 S05
S05	27.77	21.62	21.62	8.10	37.7	82.3	6.76	2.227	10.00			10.00	0.046	0.46	0.18 (0.42) 122.26 S06
S06	27.35	22.26	22.26	8.10	38.2	120.5	9.90	2.227	65.25	T	10.00	75.25	0.092	6.94	1.24 (2.85) 130.44 B01
B01	24.50	30.44	30.44			120.5	10.55	2.157	2.00	T	10.00	12.00	0.108	1.29	0.87 (2.00) 132.60 A01
A01	22.50	32.60	32.60			120.5	1.21	6.357	8.34			8.34	0.001	0.00	32.60 A02
A02	22.50	32.60	32.60		120.4	240.9	2.43	6.357	8.34			8.34	0.002	0.02	32.62 A03
A03	22.50	32.62	32.62		120.2	361.1	3.64	6.357	8.34			8.34	0.004	0.04	32.65 A04
A04	22.50	32.65	32.65		119.8	480.9	4.85	6.357	8.34			8.34	0.007	0.06	32.71 A05
A05	22.50	32.71	32.71		42.3	523.2	5.27	6.357	8.34			8.34	0.008	0.07	32.79 A06
A06	22.50	32.79	32.79		40.3	563.5	5.68	6.357	8.34			8.34	0.010	0.08	32.87 A07
A07	22.50	32.87	32.87		38.8	602.3	6.07	6.357	8.34			8.34	0.011	0.09	32.96 A08
A08	22.50	32.96	32.96		37.8	640.1	6.45	6.357	8.34			8.34	0.012	0.10	33.06 A09
A09	22.50	33.06	33.06		37.2	677.3	6.83	6.357	8.34			8.34	0.014	0.11	33.17 A10
A10	22.50	33.17	33.17		37.1	714.4	7.20	6.357	8.34			8.34	0.015	0.13	33.30 A11
A11	22.50	33.30	33.30		37.3	751.7	7.58	6.357	8.34			8.34	0.016	0.14	33.44 A12
A12	22.50	33.44	33.44		38.0	789.7	7.96	6.357	8.34			8.34	0.018	0.15	33.59 A13
A13	22.50	33.59	33.59		39.0	828.6	8.35	6.357	8.34			8.34	0.020	0.16	33.75 A14
A14	22.50	33.75	33.75		40.2	868.8	8.76	6.357	8.34			8.34	0.022	0.18	33.93 A15
A15	22.50	33.93	33.93		41.7	910.5	9.18	6.357	55.00	4L	36.00	91.00	0.024	2.14	36.07 A16
A16	22.50	36.07	36.07			910.5	9.18	6.357	20.50	AGT	65.00	85.50	0.024	2.01	8.90 (20.50) 146.98 M01 B.O.R.
M01	2.00	46.98	46.98		100.0	1010.5	6.05	8.249	2.50	4C2GL	201.00	203.50	0.008	1.63	0.43 (1.00) 149.05 M02
(C=150)															
M02	1.00	49.05	49.05			1010.5	6.26	8.110	160.00	GLT	78.58	238.58	0.006	1.38	-0.22 (-0.50) 150.20 M03
M03	1.50	50.20	50.20			AAAAA									

INSIDE HOSE

Path No: 2 Grid Line

Fed by path No.1

Ref Pt.	Elev. ft.	Pressure Pt	(psi) Pv	K Pn	Flow Factor	(gpm) Added	Veloc Total	Diam. fps	Actual in.	Fitting Length	Fitting Summary Length	Total Length	Frict.Loss per.ft	Elev. Loss Total	Next Ref Press Pt.
(C=120)															
D02	22.50	29.31	29.31			-107.0	9.37	2.157	2.00	T	10.00	12.00	0.086	-1.04	-0.87 (-2.00) 127.40 D02
D02	24.50	27.40	27.40			-107.0	8.79	2.227	45.25	T	10.00	55.25	0.074	-4.09	-0.87 (-2.01) 122.44 S07
S07	26.51	22.44	22.44	8.10	38.4	-68.6	5.64	2.227	10.00			10.00	0.033	-0.33	-0.18 (-0.42) 121.92 S08
S08	26.93	21.92	21.92	8.10	37.9	-30.7	2.52	2.227	10.00			10.00	0.007	-0.07	-0.18 (-0.42) 121.66 S09
S09	27.35	21.66	21.66	8.10	37.7	7.0	0.57	2.227	10.00			10.00	0.000	0.00	-0.18 (-0.42) 121.49 S10
S10	27.77	21.49	21.49	8.10	37.5	44.5	3.66	2.227	10.00			10.00	0.015	0.15	21.63 S11
S11	27.77	21.63	21.63	8.10	37.7	82.2	6.75	2.227	10.00			10.00	0.045	0.45	0.18 (0.42) 122.27 S12

Path Summary Printout for ARROW MOLDED PLASTICS

Job No: 01/12/1994 System: ONE Drawing: FP-3 of 3

Path No: 2 (Continued) Grid Line

Fed by path No.1

Ref Pt.	Elev. ft.	Pressure (psi) Pt	Pv	K Pn Factor	Flow (gpm) Added	Veloc (fps) Total	Diam. in.	Actual Length	Fitting Summary Length	Fitting Length	Total Length	Frict. Loss per.ft	Elev. Loss Total	Next Ref Press Pt.	
(C=120)															
S12	27.35	22.27		8.10	38.2	120.4	9.89	2.227	65.25	T	10.00	75.25	0.092	6.94	1.24 (2.85) 30.44 B02
B02	24.50	30.44				120.4	10.54	2.157	2.00	T	10.00	12.00	0.108	1.29	0.87 (2.00) 32.60 A02
A02	22.50	32.60													

Path No: 3 Grid Line

Fed by path No.1

Ref Pt.	Elev. ft.	Pressure (psi) Pt	Pv	K Pn Factor	Flow (gpm) Added	Veloc (fps) Total	Diam. in.	Actual Length	Fitting Summary Length	Fitting Length	Total Length	Frict. Loss per.ft	Elev. Loss Total	Next Ref Press Pt.	
(C=120)															
C03	22.50	29.40				-107.4	9.41	2.157	2.00	T	10.00	12.00	0.087	-1.05	-0.87 (-2.00) 27.49 D03
D03	24.50	27.49				-107.4	8.82	2.227	45.25	T	10.00	55.25	0.075	-4.12	-0.87 (-2.01) 22.49 S13
S13	26.51	22.49		8.10	38.4	-69.0	5.67	2.227	10.00		10.00	0.033	-0.33	-0.18 (-0.42) 21.97 S14	
S14	26.93	21.97		8.10	38.0	-31.1	2.55	2.227	10.00		10.00	0.008	-0.08	-0.18 (-0.42) 21.71 S15	
S15	27.35	21.71		8.10	37.7	6.7	0.55	2.227	10.00		10.00	0.000	0.00	-0.18 (-0.42) 21.53 S16	
S16	27.77	21.53		8.10	37.6	44.3	3.64	2.227	10.00		10.00	0.014	0.14	21.68 S17	
S17	27.77	21.68		8.10	37.7	82.0	6.73	2.227	10.00		10.00	0.045	0.45	0.18 (0.42) 22.31 S18	
S18	27.35	22.31		8.10	38.3	120.2	9.88	2.227	65.25	T	10.00	75.25	0.092	6.91	1.24 (2.85) 30.46 B03
B03	24.50	30.46				120.2	10.53	2.157	2.00	T	10.00	12.00	0.107	1.29	0.87 (2.00) 32.62 A03
A03	22.50	32.62													

Path No: 4 Grid Line

Fed by path No.1

Ref Pt.	Elev. ft.	Pressure (psi) Pt	Pv	K Pn Factor	Flow (gpm) Added	Veloc (fps) Total	Diam. in.	Actual Length	Fitting Summary Length	Fitting Length	Total Length	Frict. Loss per.ft	Elev. Loss Total	Next Ref Press Pt.	
(C=120)															
C04	22.50	29.60				-108.4	9.49	2.157	2.00	T	10.00	12.00	0.089	-1.06	-0.87 (-2.00) 27.67 D04
D04	24.50	27.67				-108.4	8.90	2.227	45.25	T	10.00	55.25	0.076	-4.19	-0.87 (-2.01) 22.61 S19
S19	26.51	22.61		8.10	38.5	-69.9	5.74	2.227	10.00		10.00	0.034	-0.34	-0.18 (-0.42) 22.07 S20	
S20	26.93	22.07		8.10	38.0	-31.8	2.61	2.227	10.00		10.00	0.008	-0.08	-0.18 (-0.42) 21.81 S21	
S21	27.35	21.81		8.10	37.8	6.0	0.49	2.227	10.00		10.00	0.000	0.00	-0.18 (-0.42) 21.63 S22	
S22	27.77	21.63		8.10	37.7	43.7	3.59	2.227	10.00		10.00	0.014	0.14	21.77 S23	
S23	27.77	21.77		8.10	37.8	81.4	6.69	2.227	10.00		10.00	0.045	0.45	0.18 (0.42) 22.40 S24	
S24	27.35	22.40		8.10	38.3	119.8	9.84	2.227	65.25	T	10.00	75.25	0.091	6.87	1.24 (2.85) 30.51 B04
B04	24.50	30.51				119.8	10.49	2.157	2.00	T	10.00	12.00	0.107	1.28	0.87 (2.00) 32.65 A04
A04	22.50	32.65													


Path Summary Printout for ARROW MOLDED PLASTICS

Job No: 01/12/1994 System: ONE Drawing: FP-2 of 3

Path No: 5 Far Main

Fed by path No.1

Ref Pt.	Elev. ft.	Pressure Pt	(psi) Pv	K Pn	Flow Factor	(gpm) Added	Veloc Total	Diam. in.	Actual Fitting Length	Fitting Summary Length	Total Fitting Length	Frict.Loss per.ft	Elev. Loss (ft.)	Next Ref Press Pt.
(C=120)														
C01	22.50	29.28	29.28			106.9	2.40	4.260	8.34		8.34	0.003	0.03	29.31 C02
C02	22.50	29.31	29.31		107.0	213.8	4.80	4.260	8.34		8.34	0.011	0.09	29.40 C03
C03	22.50	29.40	29.40		107.4	321.2	7.21	4.260	8.34		8.34	0.024	0.20	29.60 C04
C04	22.50	29.60	29.60		108.4	429.6	9.64	4.260	8.34		8.34	0.041	0.34	29.94 C05
C05	22.50	29.94	29.94		-42.3	387.4	8.70	4.260	8.34		8.34	0.034	0.28	30.25 C06
C06	22.50	30.25	30.25		-40.3	347.0	7.79	4.260	8.34		8.34	0.028	0.23	30.50 C07
C07	22.50	30.50	30.50		-38.8	308.2	6.92	4.260	8.34		8.34	0.022	0.19	30.71 C08
C08	22.50	30.71	30.71		-37.8	270.4	6.07	4.260	8.34		8.34	0.017	0.15	30.87 C09
C09	22.50	30.87	30.87		-37.2	233.2	5.24	4.260	8.34		8.34	0.013	0.11	31.00 C10
C10	22.50	31.00	31.00		-37.1	196.2	4.40	4.260	8.34		8.34	0.010	0.08	31.10 C11
C11	22.50	31.10	31.10		-37.3	158.8	3.57	4.260	8.34		8.34	0.007	0.05	31.16 C12
C12	22.50	31.16	31.16		-38.0	120.9	2.71	4.260	8.34		8.34	0.004	0.03	31.20 C13
C13	22.50	31.20	31.20		-39.0	81.9	1.84	4.260	8.34		8.34	0.002	0.02	31.22 C14
C14	22.50	31.22	31.22		-40.2	41.7	0.94	4.260	8.34		8.34	0.001	0.00	31.23 C15
C15	22.50	31.23	31.23			41.7	3.65	2.157	2.00 T	10.00	12.00	0.015	0.18	-0.87 (-2.00) 30.54 B15
B15	24.50	30.54	30.54			41.7	3.43	2.227	160.50 TT	20.00	180.50	0.013	2.34	32.88 B15
B15	24.50	32.88	32.88			41.7	3.65	2.157	2.00 T	10.00	12.00	0.015	0.18	0.87 (2.00) 33.93 A15
A15	22.50	33.93	33.93											



Pressure vs. Flow
 64.00 0.00
 56.00 1396.00
 0 4295.76

ARROW MOLDED PLASTICS
 INDUSTRIAL DRIVE
 NAPOLEON OH. 43545

Job Number:
 01/12/1994

DWY

