City of Napoleon

BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

Property Address.	1775 F	dustrial	Dr.		Zip: 4354.
Business Name:	City of	Posselecus 5	Date of Text	0	
Contact Person:	Jeff Ma	ribush		Title: O Perat	Sent
Phone Number	599-1891	4	Date of Test:	12-30-98	The state of the s
			NFORMATION		
Type (circle one)	(RP)	DC	VD	RPDA	DCDA
Manf/Model: Fe	beo 825 YA		Size: 2"	Serial No: AA	23471
Location of Device	e elec Dep	T. Parts C	rib N.W. C	conve	
Type of Test.	Differential Gauge	A	Sight Tube		
Outlet	Reduced Pressure			Pressure Vacuum	Breaker
Valve		•		1 TOSSAIC VACUATIO	Dicarci
Holding 🗆	Double Check Val	ve	Relief Valve	Air Inlet	Check Valve
Failed	1st Check	2nd Check			Chock varve
				*	
Test	DC psi	DCpsi	Opened at	Opened at	Held at
Results	-		3.1 psi	psi	
	Apparent		por	psi	psi
	RP 7.3 psi				
	Actual		Did Not	Did Not	Leaked
	RP 7.3 psi		Open	Open	Leaked 🗀
Date:	Pass K	Pass &	Pass X	Pass	Pass
-	Failed	Failed	Failed	Failed	Failed
			Talled 123	rance to	Faneu L.3
Repairs &					
Materials					
2710, 49.41			Onomad At	0 14	TT 11 1
Test After	DCpsi	DC psi	Opened At	Opened At	Held At
Repairs	psi	psi psi	Did Not	psi	psi
· cepants	RP psi	RP psi		Did Not	
	psi	RPpsi	Open	Open	Leaked
Date:	Pass	Dane (**)			
Date.		Pass	Pass	Pass	Pass
	Failed	Failed	Failed	Failed	Failed
F4 C:	12/ 1.	1/			
Fester Signature	Craveux	120		Certification No.	6220-064
Owner/Representa	ative Signature:	efficient !	markey		
	(11111	Y		

Tester - Goldenrod

City of Napoleon

BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

Type (circle	e one) RP	DEVICE I	NFORMATIO VB	DN RPD	A DCD
Manf/Model	Aries 2000	55	Size:4_	Serial No	2000568
	Device:				eline
Outlet	Reduced Pre	essure		Pressure Voca	um Ducolton
valve	Assembly			Pressure Vacuum Breaker	
holding	Double Check Valve		Relief	Air Inlet	Check Valv
RP DC			<u>Valve</u>		
failed	1st Check	2nd Check	₩		
RP DC					
Test	DC 3, 6 psi	DC 2.6 psi	opened at	opened at	held at
Results			psi	psi	
Pass	RP psi				
	psi		did not	did not	leaked
			open 🗌	open 🗆	louked _
Date: 4-16-02	Pass 🗆	Pass	Pass	Pass	Pass
	Failed	Failed	Failed	Failed	Failed
Repairs &					
Materials					
Test After			omoutal st		1 11
1031 ALICI	DCpsi	DC psi	opened at psi	opened at psi	held at psi
Repairs			did not	did not	Por
	RPpsi	RPpsi	open 🗆	open 🗆	leaked
Date	h	1	3D 0		Zowien, e _
Duit.		Company Company	Pass □ Failed □	Pass	Pass □ Failed □
Date:	Pass □ Failed □	Company Company	Pass Failed	Pass Failed	Pass Failed

City of Napoleon

BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

Type (circle	e one) (RP	DEVICE I	NFORMATIC VB	<u>DN</u> RPD	A DCD
Manf/Model Location of	E Febco Device: 64	825 YA Water m. I Gauge EK	eter	Serial No.	1023471
Outlet valve	Reduced Pro			Pressure Vacu	um Breaker
holding REA DC	Double Check Valve ↓		Relief Valve	Air Inlet	Check Valve
failed RP DC	1st Check	2nd Check	ţ.		
Test Results Pass	DCpsi RP_ 7.4 _psi	DCpsi	opened at	opened atpsi	held at
	ra psi		did not open □	did not open □	leaked []
Date: 4-24-62	Pass A	Pass Failed	Pass Failed	Pass □ Failed □	Pass Failed
Repairs & Materials					· ec
Test After Repairs	DCpsi	DCpsi	opened at psi did not	opened at psi did not	held at psi
•	RPpsi	RPpsi	open 🗆	open 🗆	leaked
Date:	Pass ☐ Failed ※ ☐	Pass []	Pass Failed	Pass Failed	Pass □ Failed □