

639 10

DATE	3-30-80	JOB NO.	
PROJECT	City MUNI-GARAGE		
LOCATION			
CONTRACTOR	OWNER		
WEATHER	TEMP.	° at	AM
		° at	PM
PRESENT AT SITE			
1978 NEC.			

TO _____

THE FOLLOWING WAS NOTED: **PLAN REVIEW ELECTRICAL.**

1) BLDG. CLASSIFIED AS LISTED IN ARTICLE 511 N.E.C. ARTICLES THAT APPLY.

(511-1)(511-2)(511-3)(511-5)(511-6 (a)-(b))(511-7)

2) FURNISH TO THE ELECTRICAL INSPECTOR - AVAILABLE FAULT CURRENT RATING AT LINE TERMINALS OF SERVICE EQUIPMENT. ARTICLES THAT APPLY.

(110-9)(110-10)(230-98)

3) GROUNDING - ARTICLES THAT APPLY:

(250-81(a))(250-83 (c)-(2))(250-94 (ex #1))
(250-94) TABLE.

1775 Industrial

COPIES TO _____

FIELD REPORT

SIGNED Norman Howes
Elect. Insp.