City of Napoleon BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

Type (circle	91	DC		RPD	Deb
Location of	Device: N. W	· Corner	of Blogs	Serial No	122596
Outlet	Reduced Pro	l Gauge A	Signt Tube	Pressure Vacu	um Breaker
valve	Assembly	U	Dicarei		
holding RP□ DC	Double Check Valve ↓		Relief Valve	Air Inlet	Check Valv
failed RP DC	1st Check	2nd Check	1		
Test Results Pass	DC_3,3 psi	DC_2.6_psi	opened atpsi	opened atpsi	held at
1032	RPpsi		did not open □	did not open □	leaked []
Date: 2-20-02	Pass A	Pass Failed	Pass Failed	Pass Failed	Pass Failed
Repairs & Materials	*				
Test After	DCpsi	DCpsi	opened at psi	opened at psi	held at psi
Repairs	RPpsi	RPpsi	did not open □	did not open □	leaked
Date:	Pass □ Failed - □	The second secon	Pass □ Failed □	Pass □ Pailed □	Pass □ Failed □