



City of Napoleon, Ohio

Department of Public Works

255 West Riverview Avenue, P.O. Box 151

Napoleon, OH 43545

Chad E. Lulfs, P.E., P.S., Director of Public Works

Telephone: (419) 592-4010 Fax: (419) 599-8393

www.napoleonohio.com

June 1, 2015

5 Interstate Drive
Napoleon, OH 43545

Attn: L.F. Lambert Spawn Co., Inc.

Re: 5 Interstate Drive Sewer Connection

To whom it may concern,

Thank you for your prompt response to our Illegal Sewer Connection letter. Our preliminary inspection revealed that your property had five potential illegal sewer connections. A final inspection and dye testing showed that the alleged offending connections were correctly installed into the City's storm sewer system; your property is in compliance.

Enclosed is a drawing denoting that the above referenced connections have been addressed. A copy will also be kept on record in the City of Napoleon's Engineering Department. If you have questions or require any additional information, please contact our office at 419-592-4010.

Yours truly,

Chad E. Lulfs, P.E., P.S.
Director of Public Works
City of Napoleon, Ohio

Encl.

cc: Monica Irelan, City Manager
Trevor Hayberger, City Law Director
Jeff Rathge, Operations Superintendent
Marty Crossland, Staff Engineer

5 INTERSTATE DRIVE

DATE: 5-29-15

INSPECTED BY: MARTY CROSSLAND

INVESTIGATION OF ALLEGED ILLEGAL SEWER CONNECTIONS REVEALED NO ILLEGAL CONNECTIONS AT THIS TIME. POP-UP DRAINS WERE LOCATED ON THE EAST SIDE OF THE BUILDING AND DYE TESTING CONFIRMED THE CONNECTIONS ON THE WEST SIDE TO A PRIVATE CATCH BASIN TO THE SW. THIS OUTLETS TO THE SOUTH OF THE TRACKS.

