

City of Napoleon

BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

Property Address: 845 Interstate P.O. Box 351 Zip: 43545
 Business Name: Vlastic Farms
 Contact Person: Kevin Eling Title: Area Manager
 Phone Number: 593-5060 Date of Test: 7-23-99

DEVICE INFORMATION

Type (circle one) **RP** DC VB RPDA DCDA
 Manf/Model: Wilkins 975 Size: 3" Serial No.: B05420
 Location of Device: N.E. Corner Warehouse

Type of Test: Differential Gauge Sight Tube

Outlet Valve	Reduced Pressure Assembly			Pressure Vacuum Breaker	
	Double Check Valve		Relief Valve	Air Inlet	Check Valve
	1st Check	2nd Check			
Holding <input checked="" type="checkbox"/> Failed <input type="checkbox"/>	DC _____ psi	DC _____ psi	Opened at _____ psi	Opened at _____ psi	Held at _____ psi
Test Results: <u>Pass</u>	Apparent RP <u>6.8</u> psi Actual RP <u>4.8</u> psi		Did Not Open <input type="checkbox"/> Opened at <u>3.0</u> psi	Did Not Open <input type="checkbox"/>	Leaked <input type="checkbox"/>
Date: <u>7-23-99</u>	Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/>	Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/>	Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>
Repairs & Materials					
Test After Repairs	DC _____ psi	DC _____ psi	Opened At _____ psi	Opened At _____ psi	Held At _____ psi
	RP _____ psi	RP _____ psi	Did Not Open <input type="checkbox"/>	Did Not Open <input type="checkbox"/>	Leaked <input type="checkbox"/>
Date:	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>

Tester Signature: Daniel R. Baur Certification No. 528
 Owner/Representative Signature: Kevin Eling Vlastic 7/23/99