

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 25-79 Issued 3-27-79
date

Job Location 80 Lafayette Drive
address

Lot 46 Riviera Heights 1st
sub-div or legal discript

Issued By R. Johnson
building official

Owner Harold Wagner
name tel.

Address _____

Agent Becks Construction 592-8307
builder-eng.-etc. tel.

Address 11-622 Rd. m Rt 3 Nap, Ohio

Description of Use Residence

Residential one
no. dwelling units

Commercial _____ Industrial _____

New xx Add'n. _____ Alter _____ Remodel _____

Mixed Occupancy _____

Change of Occupancy _____

Estimated Cost \$ 40,000.00

FEES	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING	\$ 69.00		\$ 69.00
<input checked="" type="checkbox"/> ELECTRICAL	5.00	20.00	25.00
<input checked="" type="checkbox"/> PLUMBING	3.00	10.00	13.00
<input checked="" type="checkbox"/> MECHANICAL			0
<input type="checkbox"/> DEMOLITION			
<input checked="" type="checkbox"/> ZONING			0
<input type="checkbox"/> SIGN			
WATER TAP	225.00		225.00
SEWER TAP	60.00		60.00
TEMP. ELECT.	10.00		10.00
ADDITIONAL PLAN REVIEW	Struct. _____ hrs	Elect. _____ hrs	
TOTAL FEES.....			\$402.00
LESS MIN. FEES PAID _____			0
		<small>date</small>	
BALANCE DUE.....			\$402.00

ZONING INFORMATION

district <u>A</u>	lot dimensions <u>See site plan</u>	area <u>30'</u>	front yd <u>30'</u>	side yds <u>30'S 20'N</u>	rear yd <u>35'</u>
max hgt <u>ok</u>	no pkg spaces <u>two ok</u>	no ldg spaces <u>n/a</u>	max cover <u>ok</u>	petition or appeal req'd <u>no</u>	date appr _____

WORK INFORMATION:

Size: Length 50' Width 59'8" Stories 1 Ground Floor Area 2265sq'

Height _____ Building Volume (for demo. permit) _____ cu. ft.

Electrical: 200 a service & 20 circuits
brief description

Plumbing: DWV & Water lines
brief description

Mechanical: Electric baseboard Heat.
brief description

Sign: _____ Dimensions _____ Sign Area _____

Additional Information: Provide following; fan in 1/2 bath, larger window in bedroom #1, proper venting in attic & crawl space; CALL FOR INSPECTIONS MARKED:

Date 3/28 Applicant Signature Robert L Beck
owner-agent

PAID
 MAR 28 1979
 CITY OF NAPOLEON

CITY OF NAPOLEON
 BUILDING INSPECTION DEPARTMENT
 APPLICATION FOR BUILDING PERMIT
 (please print or type)

The undersigned hereby makes application for construction, installation, or alteration work as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Building Codes.

Owner's Name Harold Wagner Address _____

Contractor Beck's Const Telephone No. 592-8307

Address 11622 RR 3 Nap. O.

Location of project La Fayette Drive Cost of project ~~38,000~~

Lot Information: (not required for siding job) 40,000

Lot No. 46 Subdivision Riviera Heights

Zoning District _____ Lot Size 100 ft. X 125 ft. Area _____ sq. ft.

Setbacks: Front _____ Right Side _____ Left Side _____ Rear _____

Building Information:

Residential 1 Commercial _____ Industrial _____
 No. Units

Addition _____ New Construction X Remodel _____

Accessory Building _____ Siding Alu siding
 Specific Type

Brief Description of Work: New Ranch

Size: Length 59'8" Width 50' No. of Stories one

Area: 1st Floor 1700 sq. ft. 1967 Basement _____ sq. ft.

2nd Floor _____ sq. ft. Accessory Building _____ sq. ft.

3rd Floor _____ sq. ft. Other 458 GAR sq. ft.

Additional Information: Elect Base board Heat

*APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELEVATIONS, FLOOR PLANS, CROSS SECTIONS AND PLOT PLAN. IF ADDITION OR REMODELING, SHOW ALL EXISTING STRUCTURES AND THEIR SIZE AND LOCATION. ALL PLANS SHALL BE DRAWN TO SCALE.

Date March 6 Applicant's Signature Robert L Beck

PERMIT NO. 25-79

PERMIT FEE \$ 64.00

CITY OF NAPOLEON
 BUILDING INSPECTION DEPARTMENT
 APPLICATION FOR PLUMBING PERMIT
 (please print or type)

The undersigned hereby makes application for the installation or replacement of plumbing work as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Plumbing Codes. (1, 2 and 3 family dwelling units only)

Owner's Name _____ Address _____

Plumbing Contractor _____ Telephone No. _____
 Address _____

General Contractor _____ Telephone No. _____
 Address _____

Location of Project _____ Cost of Project _____

Work Information:

No. of dwelling units 1 New Replacement _____ Addition _____

Brief description of work: New

Is water tap required yes Size 3/4" Type of Pipe Plastic

Is sewer tap required yes Size 4" Type of Pipe sea 1

Type of Water Distribution pipe Copper

Type of Drainage, Waste, and Vent pipe plastic

Size of main building drain 4" Size of main vent pipe 4"

Water Closets 2 Bathtubs 1 1 1/2 Shower 1 2"
No. No. Trap Size No. Trap Size

Lavatories 2 1 1/4 Kitchen Sink 1 1 1/2 Disposal 1 1 1/2
No. Trap Size No. Trap Size No. Trap Size

Dishwasher 1 1 1/2 Clothes Washer 1 1 1/2 Other _____
No. Trap Size No. Trap Size No. Trap Size

*All installations are subject to plumbing tests and/or inspections.

Date March 6 Applicant's Signature Robert L Beck

PERMIT NO.

PERMIT FEE \$ 13.00

CITY OF NAPOLEON
BUILDING INSPECTION DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(please print or type)

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name _____ Address _____

Electrical Contractor _____ Telephone No. _____

Address _____

General Contractor _____ Telephone No. _____

Address _____

Location of Project _____ Cost of Project _____

Work Information:

Residential ONE Commercial _____ Industrial _____

No. Units

New yes Service Change _____ Rewiring _____ Additional Wiring _____

Brief Description of Work: New

Total Floor Area - Commercial and Industrial only _____ sq. ft.

Size of proposed Service Entrance 200 Number of new circuits 20

Require Temporary Electric yes (Yes or No)

Additional Information: _____

*GROUND-FAULT CIRCUIT INTERRUPTER PROTECTION IS REQUIRED ON ALL 120-VOLT SINGLE PHASE, 15 AND 20 AMP. CIRCUITS WHICH ARE PART OF A TEMPORARY ELECTRIC SERVICE; AND ALSO ON BATHROOM, OUTDOOR, AND GARAGE RECEPTACLES IN ALL DWELLING UNITS. Art. 210-8 N.E.C.

*APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAYOUT AND RISER DIAGRAM. (FOR COMMERCIAL AND INDUSTRIAL WORK ONLY).

Date March 6 Applicant's Signature Robert J. Best

PERMIT NUMBER

PERMIT FEE \$

25.00

APPLICATION FOR PERMIT TO TAP SEWER

(Print or Type)

Owner HAROLD WAGNER NO. 579-4
Address _____ BLDG. PERMIT 25-79
Contractor BECKS CONST. PERMIT FEE \$ 60.⁰⁰
Address 11-622 R1M R4.3 NAP.O. Tel. 592-8307 DATE PAID 3-28-79
for office use only

LOCATION OF CONNECTION

Street and No. 80 LAFAYETTE DR Sanitary Storm _____
Lot No. 46 Subdivision RIVIERA HEIGHTS 1ST Size of Tap 4"
Size and Type of Sewer 4" PVC - SDR 35 ALL WORK MUST BE INSPECTED


I certify that the sewer will be used only as indicated and no other Drainage will be connected.
Date _____ Signature _____ owner-builder-agent
do not write below this line

INSPECTION RECORD

Date Inspected 3-79 Size and Type of Sewer 4" PVC - SDR 35
Location FRONT OF HSE Depth 7 1/2' @ TAP Type of Test NONE
Inspected and Approved By: [Signature] Inspector Date 3-27-79
Additional Information _____

Send copy to: BECKS CONST.

SKETCH OF INSTALLATION



CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545
(Please Print or Type)

Date 7-28-79

Permit No. 75-79

Type of Inspection FINAL

Type of Occupancy RES.

Project Name WAGNER

Address 80 LAFAYETTE

City NAP State OH

Approved

Violation

Electrical Contractor BECK

Remarks:

Code Reference

Not Home 3:30 PM

Final except

Service Drop to clear roof by 3/4"

Compliance Time

Inspectors Signature M. Howes

Copies To:

White - Applicant Yellow - Engineering Pink - Electrical Inspector

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545
(Please Print or Type)

Date 7-28-79

Permit No. 25-79

Type of Inspection FINAL

Type of Occupancy RES.

Project Name WAGNER

Address 80 LAFFAYETTE

City NAP State O

Approved

Violation

Electrical Contractor BECK

Remarks:

Code Reference

Not Home 2:30 PM

Final except

Service Drop to Clear roof by 3 ft.

Compliance Time

Inspectors Signature M. Howes

Copies To:

White - Applicant Yellow - Engineering Pink - Electrical Inspector

TECHNICAL INSPECTION FIELD REPORT

Project Name: [Faint text]
Location: [Faint text]
Date: [Faint text]

Date: 7-27-11
Project No: 25-11
Inspector: [Faint text]
City of Boston: [Faint text]

Inspector: [Faint text]
City of Boston: [Faint text]

1. Description of Work

2. Findings

3. Recommendations

Inspector: [Faint text]

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Date 6-2-79

Permit No. 25-79

Type of Inspection ROUGH & SERVICE

Type of Occupancy RES.

Project Name HAROLD WAGNER

Address 80 LAFAYETTE DR

City NAP State OH

✓ on FINAL

Approved

Violation ✓

Electrical Contractor BECK

Remarks:

Code Reference

NDPA - CHECK MAST ON SERVICE

When a roof has a slope of 4/12 or greater the service conductor must clear the highest point of roof by 3 feet.

and 230-24 (a) 34(1) part 1

Compliance Time

Inspectors Signature H. Howell

Copies To:

White - Applicant Yellow - Engineering Pink - Electrical Inspector

