

THE CITY OF NAPOLEON

BUILDING & ZONING DEPARTMENT

255 W. RIVERVIEW

(419)592-4010

WATER YOKE RELEASE ONLY Permit

Page 1 of 1

Permit Number: WT2006-1

Printed: 2/6/2006

Property Address: 230 Lagrange St.

Applicant

Address: Rupp Rosebrock, Inc.

Approval Date: 2/6/2006

Phone:

Owners

Name: R & M Co.
15465 Co Rd M1
Napoleon, OH 43545

Phone: 419-592-3283

Contractors

Fees and Receipts:

Number	Description	Amount
FEE2006-125	Water 1" meter	\$425.00

Total Fees: \$425.00

Description of work to be done:

Samuel Mancino/ Water yoke

Applicant signature: _____ Date: _____

THE CITY OF NAPOLEON

BUILDING & ZONING DEPARTMENT

255 W. RIVERVIEW

(419)592-4010

WATER YOKE RELEASE ONLY Permit

Page 1 of 1

Permit Number: WT2006-1

Printed: 2/6/2006

Property Address: 230 Lagrange St.

Applicant

Address: Rupp Rosebrock, Inc.

Approval Date: 2/6/2006

Phone:

Owners

Name: R & M Co.
15465 Co Rd M1
Napoleon, OH 43545

Phone: 419-592-3283

Contractors

Fees and Receipts:

Number	Description	Amount
FEE2006-125	Water 1" meter	\$425.00

Total Fees: \$425.00

Description of work to be done:

Samuel Mancino/ Water yoke

Applicant signature: _____ **Date:** _____



TESTED FOR: Mr. Dave Manahan
R & M Company
15465 County Road M-1
Napoleon, Ohio 43545

PROJECT: Pavement Coring
& Profiles
Lagrange Street
Napoleon, Ohio

DATE: February 3, 2005

OUR REPORT NO: 125-50006-1

As requested, PSI representatives reported to the project location at Lagrange Street, just east of Scott Street in Napoleon, Henry County, Ohio, to perform coring operations.

The coring operations were conducted to obtain drilled core specimens and determine pavement profiles of the in-place pavement. PSI performed coring operations at three (3) locations as noted on the attached sketch. After removal of the cores, the thickness of the cores and base course stone was noted using standard measuring methods. The cored holes were backfilled and patched with asphalt/concrete mixture.

Listed below are the pavement profiles per each noted location.

Location	Asphalt Thickness (inches)	Aggregate Base Course Thickness (inches)
C-1	6-1/2"	2-1/2"
C-2	8-1/2"	2-1/2"
C-3	8"	2-1/2"

If you have any questions regarding this report, please contact us at your convenience at (419) 999-5660.

Respectfully submitted,

Professional Service Industries, Inc.

Raymond G. France
Branch Manager

Page two of two
February 3, 2005

R & M Company
Pavement Coring and Profiles
Lagrange Street
Napoleon, Ohio
PSI Report No. 125-50006-1
Professional Service Industries

