


DATE: 7-20-15  
INSPECTED BY: MARTY CROSSLAND

235 LAGRANGE STREET



AN INVESTIGATION OF ILLEGAL SEWER CONNECTIONS REVEALED NO SUCH CONNECTIONS. ALL DOWNSPOUTS ARE CONNECTED TO AN AREA DRAIN IN THE DRIVEWAY AND ALL OUTLET TO THE CREEK.





# City of Napoleon, Ohio

## Department of Public Works

255 West Riverview Avenue, P.O. Box 151

Napoleon, OH 43545

Chad E. Lulfs, P.E., P.S., Director of Public Works

Telephone: (419) 592-4010 Fax: (419) 599-8393

[www.napoleonohio.com](http://www.napoleonohio.com)

July 20, 2015

235 LaGrange Street  
Napoleon, OH 43545

Attn: Charles Stover

Re: 235 LaGrange Street Sewer Connection

Dear Mr. Stover,

Thank you for your prompt response to our Illegal Sewer Connection letter. Our preliminary inspection revealed that your property had four potential illegal sewer connections. A final inspection showed that the offending connections are correctly installed to outlet all three downspouts and a driveway drain to the nearby creek; your property is in compliance.

Enclosed is a drawing denoting that the above referenced connections have been addressed. A copy will also be kept on record in the City of Napoleon's Engineering Department. If you have questions or require any additional information, please contact our office at 419-592-4010.

Yours truly,

Chad E. Lulfs, P.E., P.S.  
Director of Public Works  
City of Napoleon, Ohio

Encl.

cc: Monica Irelan, City Manager  
Trevor Hayberger, City Law Director  
Jeff Rathge, Operations Superintendent  
Marty Crossland, Staff Engineer