

FIELD CORRECTION NOTICE

LOCATION 1212 Lakeview PERMIT NO. 2799

ISSUED TO Gary Wagner  
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO Gary Wagner

Upon inspection, violations of the CABO Sec. 200 were in evidence.

The following orders are hereby issued for their correction: Reinstall electrical  
mast flashing, furnace vent flashing + plumbing vent  
flashing. Cover exposed skirt in valley area  
west wing. Install additional down spout  
southwest corner of South west bedroom. Replace  
chimney counter flashing.

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE 4-10-93

DATE 3-26-93

BY [Signature] INSPECTOR

PINK - ORIGINAL COPY    WHITE - FIELD COPY    YELLOW - FILE COPY

FIELD CORRECTION NOTICE

LOCATION 1212 Lakeview PERMIT NO. 12777

ISSUED TO Gary Wagner  
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO Gary Wagner

Upon inspection, violations of the CABO Sec. 200 were in evidence.

The following orders are hereby issued for their correction:

most flashing, remove vent + locking + planting vent  
flashing, or remove + start in wall +  
vent + wing. Install additional down spout  
southwest corner + south west bedroom. Replace  
chimney counter + locking.

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE 4-10-13

DATE 3-26-13 BY [Signature] INSPECTOR

PINK - ORIGINAL COPY    WHITE - FIELD COPY    YELLOW - FILE COPY