

## Wood County Building Inspection

Michael J. Rudey, Chief Building Official

*Board of County Commissioners*

*Craig LaHote . Doris I Herringshaw. Dr. Theodore Bowlus*



---

One Courthouse Square · Bowling Green, OH 43402 · Phone (419) 354-9190 ·  
Fax (419) 373-6786

[buildinginspection@co.wood.oh.us](mailto:buildinginspection@co.wood.oh.us) · <http://wcbinspect.co.wood.oh.us>

December 18, 2019

Job No: 19-003720

Permit No: B19-001316

Job Name: GILLEN, STEPHANIE

Location: 22 LAKEVIEW DRIVE

Twp./Corp.: Napoleon Corp.

Applicant: Stephanie Gillen - Stephanie Gillen

Reviewed by: Bryon Traynoff

### **Approval: (No Conditions)**

**Note!** Per Section 106.1 and 107.1 of the 2017 Ohio Building Code or Section 105.1 of 2013 Residential Code of Ohio; the documents as submitted for the above referenced project have been reviewed and found to be in compliance with the Ohio Building Codes and the applicable reference standards.

22 Lakeview Napoleon OH 43534S  
 Replacement Steps for Deck

Handrail height shall be 34"-38"  
 From top of landing or top of Tread nosing - per 311.8.3

- Per 311 -
- Risers shall NOT exceed 3/8" difference between Riser to Riser.
- Riser height shall NOT exceed 8 1/4" in height.
- Tread depth shall NOT be less than 9" deep.

