

**CITY OF NAPOLEON  
BUILDING CONSTRUCTION PERMIT  
(1, 2 or 3 Family Dwelling)**

Owner Name Lara Kruse

Address 652 Leonard Street

Builder Name Harold Bestelman

Address 618 Park Street Tel. 592-2383

**Lot Information:**

Street No. 652 Leonard St.

Lot # 116 Subdivision Sheffields 3rd Add.

Lot Dimensions ..... Lot Area ..... Sq. Ft.

Yard Set Back: Front ..... Rear .....  
Side ..... Side .....

Zoning "B" Intended use of Building: Installing a new 100 amp electric service entrance.

Permit No.	<u>600-76</u>		
Issued	<u>September 20, 1976</u>		
By	<u>Thomas W. Shaw</u> Building Inspector		
Valuation	<u>\$350.00</u>		
<b>Fees</b>	<b>Base</b>	<b>Plus</b>	<b>Total</b>
Construction	.....	.....	.....
Plumbing	.....	.....	.....
Electrical	<u>\$3.00</u>	.....	<u>\$3.00</u>
Heating	.....	.....	.....
Water Tap	.....	.....	.....
Sewer Tap	.....	.....	.....
Temporary Elec.	.....	.....	.....
<b>TOTAL</b>	<u>\$3.00</u>	.....	<u>\$3.00</u>

**Building Information:**

Single  Double ..... Multiple ..... New Construction ..... Addition ..... Remodel

Size: Length ..... Width ..... No. of Stories .....

Floor Area: 1st Floor ..... 2nd Floor ..... 3rd Floor ..... Basement .....

Unfinished Attic ..... Garage .....

Foundation: Piers ..... Full Basement ..... Part Basement .....

Concrete ..... Block .....

Walls: Frame ..... Block ..... Brick ..... Other .....

Electrical: Wiring New 100 Amp Electric Heating ..... Electrical Appliances .....

Plumbing: Fixtures or Traps ..... Warm Air Heating ..... Hot Water Heating .....

Additional Information: .....

Date 9-20-76 Applicant Signature Harold Bestelman  
Owner - Builder - Agent

**Inspection Record:**

Work Started ..... Foundations ..... Plumbing, Heating .....

Set Back, Side Lines ..... Plumbing (Rough In) ..... And Air Conditioning .....

Excavation ..... Erecting Frame ..... Roof .....

Footing ..... Electrical Work SERVICE ONLY APPROVED BY HOWES 11/5/76

Comments: 11/5/76 READ ATTACHED NOTICE FOR VIOLATIONS.

Certificate of Occupancy Issued .....

Pink - Engineer

Inspector

CITY OF NAPOLEON

Building Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545  
(Please Print or Type)

Date November 5, 1976

Permit No. 600-76

Type of Inspection Electrical Service

Existing

Type of Occupancy Single Family

Project Name Lora Kruse

Address 652 Leonard Street

City Napoleon State Ohio

Approved

Violation X

Electrical Contractor Harold Bostelman

Remarks:

Code Reference

If you installed splices in N.M. cable below service equipment panel in attic then please correct by making up splices in a junction box.

N.E.C. 75'

NOTE: 1/11/76 HAROLD BOSTELMAN INFORME ME HE DID NOT INSTALL SPLICES, PWP, THIS WAS EXISTING WORK.

Please contact the Building Department when this condition is corrected for re-inspection.

Compliance Time 30 days from time of this notice.

Inspectors Signature Norman Howell

Copies To: Harold Bostelman

CITY OF NAPOLEON  
ENGINEERING DEPARTMENT  
APPLICATION FOR ELECTRICAL PERMIT  
(PLEASE PRINT OR TYPE)

The undersigned hereby makes application for the installation, replacement or alteration of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Code for 1, 2 and 3 Family Buildings.

Owner's Name LORA-KRUSE Address 652 LEONARD ST

Contractor's Name HAROLD-BOSTELMAN Address 618 PARK Tel. 692-2383

LOT INFORMATION:

Location of Project \_\_\_\_\_ Lot # \_\_\_\_\_

Subdivision \_\_\_\_\_ Zoning District \_\_\_\_\_

BUILDING INFORMATION:

Single Family  Double Family \_\_\_\_\_ Multiple Family \_\_\_\_\_

New Construction \_\_\_\_\_ Existing \_\_\_\_\_ Addition \_\_\_\_\_

Replacement \_\_\_\_\_ Remodel \_\_\_\_\_ Service Change

Size: Total Square Foot Per Floor \_\_\_\_\_ No. of Stories \_\_\_\_\_

DESCRIPTION OF WORK

Size of Service 100 AMP. Service Change Only YES (Yes or No)

Total Number of New Circuits NONE Total Number of New Circuits Excluding Appliance Circuits \_\_\_\_\_

APPLIANCE CIRCUITS: (indicate quantity)

Electric Range \_\_\_\_\_ Range Hood \_\_\_\_\_ Clothes Dryer \_\_\_\_\_ Dishwasher \_\_\_\_\_

Air Conditioner \_\_\_\_\_ Attic Fan Blower \_\_\_\_\_ Room Exhaust Fan \_\_\_\_\_

Disposal \_\_\_\_\_ Hot Water Heater \_\_\_\_\_ Electric Oven \_\_\_\_\_

Require Temporary Electric NO (Yes or No)

Note: G.F.I.C. required for all temporary electric with approved ground rod at service.

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAY-OUT AND RISER DIAGRAM.

ESTIMATED COST OF COMPLETED PROJECT: \$350.00

DATE SEPT. 14-1976 APPLICANT'S SIGNATURE Harold Rostelman  
OWNER-CONTRACTOR-AGENT