

# PERMIT

## CITY OF NAPOLEON - BUILDING DEPARTMENT

255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 1107 Issued 10/22/85 date

Job Location 901 Lyme address

Lot \_\_\_\_\_ sub-div or legal discript

Issued By Richard G. Hayman building official

Owner Napoleon City Schools name 599-7015 tel.

Address Briarheath Drive

Agent Spicer Electric builder-eng.-etc. \_\_\_\_\_ tel. \_\_\_\_\_

Address \_\_\_\_\_

Description of Use St Paul School - Federal Reading Program - Electric Service

Residential \_\_\_\_\_ no. dwelling units \_\_\_\_\_

Commercial \_\_\_\_\_ Industrial \_\_\_\_\_

New \_\_\_\_\_ Add'n. \_\_\_\_\_ Alter \_\_\_\_\_ Remodel \_\_\_\_\_

Mixed Occupancy \_\_\_\_\_

Change of Occupancy \_\_\_\_\_

Estimated Cost \$ 40000

FEES	BASE	PLUS	TOTAL
<input type="checkbox"/> BUILDING			
<input checked="" type="checkbox"/> ELECTRICAL			80.00
<input type="checkbox"/> PLUMBING			
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> DEMOLITION			
<input type="checkbox"/> ZONING			
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs	Elect. _____ hrs	
TOTAL FEES.....			80.00
LESS MIN. FEES PAID _____ date _____			-0-
BALANCE DUE.....			80.00

### ZONING INFORMATION

district	lot dimensions	area	front yd	side yds	rear yd
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

PAID

APR 2 1986

CITY OF NAPOLEON

### WORK INFORMATION:

Size: Length \_\_\_\_\_ Width \_\_\_\_\_ Stories \_\_\_\_\_ Ground Floor Area \_\_\_\_\_

Height \_\_\_\_\_ Building Volume (for demo. permit) \_\_\_\_\_ cu. ft.

Electrical: \_\_\_\_\_ brief description \_\_\_\_\_

Plumbing: \_\_\_\_\_ brief description \_\_\_\_\_

Mechanical: \_\_\_\_\_ brief description \_\_\_\_\_

Sign: \_\_\_\_\_ type \_\_\_\_\_ Dimensions \_\_\_\_\_ Sign Area \_\_\_\_\_

Additional Information: \_\_\_\_\_

Date 4/2/86 Applicant Signature St. Paul School / St. Paul Lutheran owner-agent

FIELD CORRECTION NOTICE

LOCATION 901 Lynne Street PERMIT NO. 1107

ISSUED TO Napoleon City Schools / St Paul School  
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO Speiser Electric

Upon inspection, violations of the 1984 NEC 550-9-D-1  
Sec. 550-23-E were in evidence.

The following orders are hereby issued for their correction: Equipment grounding conductor shall be  
connected to grounding bus in service panel. Service equipment shall be  
grounded. Electrode is required.

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE  
AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE Final approval shall be given

DATE 23 MAY 86 BY Paul E. Bushman  
INSPECTOR

PINK - ORIGINAL COPY WHITE - FIELD COPY YELLOW - FILE COPY