

PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. 313 Date July 27, 1981
Job Location 228 E. Main St. Valuation \$ 5,797.00
Owner Matilda Schultz Address 228 E. Main St.
Contractor Cornerstone Construction Telephone No. 782-7846
Address 418 Auglaize St., Defiance, Ohio
Electric Contractor _____
Plumbing Contractor _____
Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:

Residential X Commercial _____ Industrial _____
No. dwelling units
New Construction _____ Addition _____ Remodel X
Brief Description of Work Rehab. for CDBG program

ISSUED BY Richard G. Hayman DEPT. OF BUILDING & ZONING
Building Official

It is the owners or contractors responsibility to call the Building Department for the following (X) inspections:

- _____ Footing excavation prior to placing concrete.
- _____ Footing drains and foundation prior to backfill.
- _____ Prepared sub-grade prior to placing concrete floor slab.
- _____ Sanitary sewer
- X _____ Rough-in electrical, plumbing and service framing prior to installing wall board.
- X _____ Final electrical, plumbing and heating.
- X _____ Final building inspection, prior to occupancy.

PERMIT & FEES

Building Permit	\$ <u>18.00</u>
Electrical Permit	\$ <u>9.00</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other	\$ _____

TOTAL FEES \$ 27.00

LESS FEES PAID \$ -0.00

BALANCE DUE \$ 27.00

PAID
JUL 28 1981

CITY OF NAPOLEON

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

CITY OF NAPOLEON
BUILDING INSPECTION DEPARTMENT
APPLICATION FOR BUILDING PERMIT
(please print or type)

The undersigned hereby makes application for construction, installation, or alternation work as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Building Codes.

Location of project 228 E. MAIN ST Cost of Project \$ 5,797.00

Owner's Name MATILDA SCHULTZ Address 228 E. MAIN ST

Contractor CORNERSTONE CONSTRUCTION Telephone No. 782-7846

Address 418 AUGLAIZE ST DEFIANCE, OHIO

Lot Information: (not required for siding job)

Lot No. _____ Subdivision _____

Zoning District GB Lot Size _____ ft X _____ ft. Area _____ sq. ft.

Setbacks: Front _____ Right Side _____ Left Side _____ Rear _____

Work Information:

Residential Commercial _____ Industrial _____

New Construction _____ Addition _____ Remodel

Accessory Building _____ Siding ALUMINUM OR VINYL
Specific Type _____

Brief Description of Work: REHABILITATION FOR CDBG PROGRAM

Size: Length _____ Width _____ No. of Stories 2

Area: 1st Floor _____ sq. ft. Basement _____ sq. ft.

2nd Floor _____ sq. ft. Accessory Building _____ sq. ft.

3rd Floor _____ sq. ft. Other _____ sq. ft.

Additional Information: _____

*APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELEVATIONS, FLOOR PLANS, CROSS SECTIONS AND PLOT PLAN. IF ADDITION OR REMODELING, SHOW ALL EXISTING STRUCTURES AND THEIR SIZE AND LOCATION. ALL PLANS SHALL BE DRAWN TO SCALE.

Date _____ Applicant's Signature _____

PERMIT NO.

313

PERMIT FEE \$ 18.00

CITY OF NAPOLEON
BUILDING INSPECTION DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(Please print or type)

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name MATILDA SCHULTZ Address 228 E. MAIN ST

Electrical Contractor WOLLACE ELEC. Telephone No. _____

Address STRYKER OHIO

General Contractor CORNERSTONE CONSTRUCTION Telephone No. 782-7846

Address 418 AUGLAIZE ST. DEFIANCE, OHIO

Location of Project _____ Cost of Project _____

Work Information:

Residential 1 Commercial _____ Industrial _____

No. Units

New _____ Service Change _____ Rewiring _____ Additional Wiring _____

Brief Description of Work: _____

Size of proposed service entrance 100 AMPS Number of new circuits 4

Type of proposed service entrance _____ Underground _____ Overhead X

Require Temporary Electric 7 (Yes or No)

Total Floor Area - Commercial and Industrial only _____ sq. ft.

Additional Information: _____

*Ground fault circuit interrupter protection is required on all 120-volt single phase, 15 and 20 amp. Circuits which are part of a temporary electric service; and also on bathroom, outdoor, and garage receptacles in all dwelling units. Art. 210-8 N.E.C.

*Application for permit shall be accompanied by two complete sets of plans including: Electrical layout and riser diagram. (For commercial and industrial work only).

Date _____ Applicant's Signature _____

- X ROUGH ELEC. ETC.
- X FINAL ELEC
- X FINAL BLOC

PERMIT NO. 313
PERMIT FEE \$ 9.00

PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. 313 Date July 27, 1981
Job Location 228 E. Main St. Address Valuation \$ 5,797.00
Owner Matilda Schultz Name Address 228 E. Main St.
Contractor Cornerstone Construction Telephone No. 782-7846
Address 418 Auglaize St., Defiance, Ohio
Electric Contractor _____
Plumbing Contractor _____
Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:

Residential Commercial _____ Industrial _____
No. dwelling units
New Construction _____ Addition _____ Remodel
Brief Description of Work Rehab. for CDBG program

ISSUED BY _____ Building Official DEPT. OF BUILDING & ZONING

It is the owners or contractors responsibility to call the Building Department for the following (X) inspections:

- _____ Footing excavation prior to placing concrete.
- _____ Footing drains and foundation prior to backfill.
- _____ Prepared sub-grade prior to placing concrete floor slab.
- _____ Sanitary sewer
- _____ Rough-in electrical, plumbing and service framing prior to installing wall board.
- _____ Final electrical, plumbing and heating.
- _____ Final building inspection, prior to occupancy.

PERMIT & FEES

Building Permit	\$ <u>18.00</u>
Electrical Permit	\$ <u>9.00</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other _____	\$ _____

TOTAL FEES \$ 27.00
LESS FEES PAID \$ -0-
BALANCE DUE \$ 27.00

PAID
JUL 28 1981
CITY OF NAPOLEON

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

INSPECTION RECORD

UNDERGROUND		ROUGH-IN			FINAL			
Type	Date	By	Type	Date	By	Type	Date	By
PLUMBING								
Sewer Connection			Drainage, W. & Vent			Drainage, W. & Vent		
Building Sewer			Water Piping			Water Heater		
Water Piping			Condensate Lines			Backflow Prevention		
			Indirect Waste					
ELECTRICAL								
Floor Ducts Raceways			Rough Wiring	3-29	JCC	Electric Mtr. Clearance	3-29	JCC
Conduits & Cable			Conduits/Cable			Signs		
Grounding & Bonding	3-29	JCC	Service Panel Switchboard	3-29	JCC			
			Subpanels					
			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			FINAL APPROVAL	3-29	JCC
MECHANICAL								
Refrigerant Piping			Refrigerant Piping			Duct Insulation		
Ducts/Plenums			Ducts/Plenums			Chimney(s)		
			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.			Furnace(s)		
			Wall Construction			FINAL APPROVAL		
Location, Set-backs, Esmt(s)			Excavation			Fireplace Chimney		
			Footings & Reinforcing			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access		
			Sub-soil Drain			Special Insp Reports Rec'd		
			Foundation Walls			Smoke Detector	3-29	JCC
			Floor Slab			Demolition (sewer cap)		
						Building or Structure	3-29	JCC
FINAL APPROVAL BLDG. DEPT			FINAL APPROVAL			Certificate of Occupancy Issued		#
							3-29	JCC

Roof p- 24, 25, 26, 27
 Change order - Rim Joist - 9-1-81
 " 2 STRIPS FASCIA 9-2-81

Roof repaired 1-4-82
 some electrical changes remain to be done

Roof repaired twice. so far no new complaint 3-29-82

Woodac Electric returned to make necessary electric changes - February 1982.

House meets contract CDCC 3-29-82 JCC