

DATE: 9-29-15

INVESTIGATION OF ILLEGAL SEWER CONNECTIONS REVEALED FOUR (4) ILLEGAL DOWNSPOUT CONNECTIONS TO THE SANITARY SEWER. THESE HAVE ALL BEEN CORRECTED AND ALL ARE IN COMPLIANCE AT THIS TIME.

526 EAST MAIN STREET

