

316-318 W Main



City of Napoleon, Ohio

Engineering Department

255 West Riverview Avenue, P.O. Box 151

Napoleon, OH 43545

Chad E. Lulfs, P.E., P.S., City Engineer

Telephone: (419) 592-4010 Fax: (419) 599-8393

www.napoleonohio.com

November 9, 2011

Steve Meyer
159 Highland Avenue
Avon Lake, Ohio 44012

Re: Sanitary Sewer Relocation Notice
316 W. Main Street, Napoleon, Ohio

Dear Mr. Meyer,

It has come to the City of Napoleon's attention that the sewage from your property at the address listed above is emptying onto the ground. Per Ohio E.P.A. orders and the City of Napoleon's Water & Sewer Rules, this is prohibited.

This letter is to alert you of the situation and to serve notice that this issue must be corrected immediately. You are hereby directed to repair/replace your sanitary sewer service. You have ten (10) calendar days from the date of this letter to complete the required repairs/replacement. If the required work is not completed, legal action may be taken. Also, all water service to the property shall be terminated.

If you have any questions or require additional information, please contact us at your convenience.


Yours truly,

A handwritten signature in black ink, appearing to read "Chad E. Lulfs", is written over a faint, circular official stamp or seal.

Chad E. Lulfs, P.E., P.S.
City of Napoleon Engineer

cc: Jon A. Bisher, City Manager

Setup 9	Surveyor Roger Darr	Certificate # U-906-3742	System Owner		
Drainage	Survey Customer City of Napoleon				
P/O #	Date 2011/10/05	Time 9:18	Street W Main		
City Napoleon	Further location details				
Start AVON	Rim to invert	Grade to invert	Rim to grade	Ft	
Finish WEBSTER	Rim to invert	Grade to invert	Rim to grade	Ft	
Use Combined	Direction Downstream	Flow control Not Controlled	Media No 1		
Shape Circular	Height 15	Width ins	Preclean J	Year Cleaned 2011/10/04	
Material Vitrified Clay Pipe	Joint length	Ft	Total length	Ft	Length Surveyed 403.10
Lining	Year laid	Year rehabilitated	Weather Damp		
Purpose Routine Assessment	Cat				
Additional info			Structural	O&M	Constructional
Location Light Highway			Miscellaneous	Hydraulic	



DATE: 7-20-11

INSTALLED BY: TRESSLER PLUMBING

INSPECTED BY: MARTY CROSSLAND

1"=10'

DATE: 11-22-11

INSTALLED BY: VERNON NAGEL, INC.

INSPECTED BY: MARTY CROSSLAND

N

316

318

6" TO 4" RED

6" c/o 2.5' DEEP FIL

6'
45°

21'

45° 4.5' DEEP FIL

12'

45° DOWN
6" c/o 5.5' DEEP FIL

2-45° BENDS
8' DEEP FIL
PERMCO TO
EX 6" VIT.

ABANDONED
6" VIT. 5.5' DEEP

NOTE: TRESSLER INSTALLED FROM HOUSE TO 2ND CLEANOUT. VERNON NAGEL INSTALLED FROM CLEANOUT TO SIDEWALK.

WEST MAIN STREET

CITY OF NAPOLEON ZONING PERMIT APPLICATION

THIS APPLICATION IS FOR RESIDENTIAL DEMOLITIONS, FENCES, POOLS, SHEDS,
DRIVEWAYS, SIDEWALKS & SEWERS

DATE 7-6-11 JOB LOCATION ~~318~~ 316-318 W. Main

OWNER Steve Meyer TELEPHONE # _____

OWNER ADDRESS 159 Highland, Avon Lake, OH 44012

CONTRACTOR Tressler Plumbing CELL PHONE # _____

DESCRIPTION OF WORK TO BE PERFORMED _____

ESTIMATED COMPLETION DATE _____ ESTIMATED COST _____

DESCRIPTION	FEE	TOTAL COST
Demo Permit	(100.3100.46690) \$100.00	\$
Fence	(100.3100.46690) \$25.00	\$
Pool	(100.3100.46690) \$25.00	\$
Garage and Shed Under 200 SF (Detached)	(100.3100.46690) \$25.00	\$
Driveway	0	\$
Sidewalk/Curbing	0	\$
Sewer Outside	0	\$
Subtotal:		\$
		\$
TOTAL FEE:		\$

Doug Tressler called on 7-6-11. Said he would be in tomorrow to sign and pick up the permit.
7-7-11 Doug signed ^{permit} ~~permit~~ but not the application.

I FULLY UNDERSTAND THAT NO EXCAVATION, CONSTRUCTION OR STRUCTURAL ALTERATION, ELECTRICAL OR MECHANICAL INSTALLATION OR ALTERATION OF ANY BUILDING STRUCTURE, SIGN, OR PART THEREOF AND NO USE OF THE ABOVE SHALL BE UNDERTAKEN OR PERFORMED UNTIL THE PERMIT APPLIED FOR HEREIN HAS BEEN APPROVED AND ISSUED BY THE CITY OF NAPOLEON BUILDING/ZONING DEPARTMENT.

I hereby certify that I am the Owner of the named property, or that the proposed work is authorized by the Owner of record and that I have been authorized by the Owner to make this application as his/her authorized agent and I agree to conform to all applicable laws of the jurisdiction. In addition, if a permit for Work described in this application is issued, I certify that the code official or the code official's authorized representative shall have the authority to enter areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit.

I HEREBY ACKNOWLEDGE THAT I HAVE READ AND FULLY UNDERSTAND THE ABOVE LISTED INSTRUCTIONS.

SIGNATURE OF APPLICANT: _____ DATE: _____

PRINT NAME: _____

BATCH #	CHECK #	DATE
---------	---------	------

SCANNED

9-7-11



Permit Report

Outside Sewer

Issued By

City of Napoleon
255 W. Riverview
Napoleon, OH 43545
Phone: 419-592-4010
Fax: 419-599-8393
Email: khonemann@napoleonohio.com

Permits#: P-KH-11-0041

Valid Dates: From 7/6/2011 To 7/6/2011

Issued To

Tressler Plumbing
PO Box 433(CON-123)
Defiance, OH 43512
Phone: 419-782-1256

Outside Sewer work at:
316 & 318 W. Main St.

Item	Date	Record Ref.	Unit Price	Qty	Amount
1					
Total:					

Applicant Signature

Issuing Official Signature