

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01271 Issued 11-7-86 date

Job Location 710 W. Main address

Lot 160 Sheffield's Third Add. sub-div or legal discript

Issued By Eldon Huber building official

Owner Doug Lang 592-5601 name tel.

Address 710 W. Main

Agent Napoleon Lumber Co. 592-7796 builder-eng.-etc. tel.

Address N. Scott Street

Description of Use Residence

Residential 1 no. dwelling units

Commercial _____ Industrial _____

New _____ Add'n. X Alter _____ Remodel _____

Mixed Occupancy _____

Change of Occupancy _____

Estimated Cost \$ 20,000.00

FEES	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING	3.00	36.00	39.00
<input checked="" type="checkbox"/> ELECTRICAL	5.00	8.00	13.00
<input type="checkbox"/> PLUMBING			
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> DEMOLITION			
<input type="checkbox"/> ZONING			
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs	Elect. _____ hrs	
TOTAL FEES.....			\$52.00
LESS MIN. FEES PAID _____			
BALANCE DUE.....			

ZONING INFORMATION

district	lot dimensions	area	front yd	side yds	rear yd
B	38.85' + X 132' +	4,905 S.F.	25' Min.	5' Min.	15' Min.
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr
35' Max.	2 -MIN.		45' Max.		

WORK INFORMATION:

Size: Length 22'-6" Width 19'-0" Stories 2 Ground Floor Area 371.5 S.F.

Height 24'-0" Building Volume (for demo. permit) _____ cu. ft.

Electrical: Add Approximately 8 Circuits brief description

Plumbing: Apply for seperately brief description

Mechanical: Apply for seperately brief description

Sign: N.A. Dimensions _____ Sign Area _____

Additional Information: 2 - Story Addition to the North end of the existing residence.

Date _____ Applicant Signature Douglas C Lange NOV 7 1986
owner-agent

PAID

CITY OF NAPOLEON

INSPECTION RECORD

	UNDERGROUND			ROUGH-IN						FINAL		
	Type	Date	By	Type	Date	By	Type	Date	By	Type	Date	By
PLUMBING	Building Drains			Drainage, Waste & Vent Piping			Indirect Waste			Drainage, Waste & Vent Piping		
	Water Piping									Backflow Prevention		
	Building Sewer			Water Piping			Condensate Lines			Water Heater		
	Sewer Connection									FINAL APPROVAL		
MECHANICAL	Refrigerant Piping			Refrigerant Piping			Chimney(s)			Grease Exhaust System		
				Duct Furnace(s)			Fire Dampers			Air Cond. Unit(s)		
	Ducts/Plenums			Ducts/Plenums			<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)			Refrigeration Equipment		
				Duct Insulation			Pool Heater			Furnace(s)		
				Combustion Products Vents			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.			FINAL APPROVAL		
ELECTRICAL	Conduits & or Cable			Conduits/Cable			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			Temp Service Temp Lighting		
	Grounding & or Bonding			Rough Wiring			<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors			Fixtures Lampholders		
	Floor Ducts Raceways			Service Panel Switchboard			<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder			Signs		
	Service Conduit			Busways Ducts			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable			Electric Mtr. Clearance		
	Temporary Power Pole			Subpanels			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)			FINAL APPROVAL		
BUILDING	Location, Set-backs, Esmt(s)	10/16	EH	Exterior Wall Construction ①	11/5	EH	Roof Covering Roof Drainage			Smoke Detector		EH
	Excavation	10/16	EH				Exterior Lath			Demolition (sewer cap)		
	Footings & Reinforcing	10/16	EH				<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard					
	Floor Slab			Interior Wall Construction			Fire Wall(s)			Building or Structure		EH
	Foundation Walls			Columns & Supports			Fireplace Chimney					
	Sub-soil Drain			Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access					
	Piles			Floor System(s)	11/5	EH				FINAL APPROVAL BLDG. DEPT.		EH
				Roof System			Special Insp Reports Rec'd			Certificate of Occupancy Issued		
ADDITIONAL	INSPECTIONS, CORRECTIONS, ETC.						INSPECTIONS, CORRECTIONS, ETC.					
	ROUGH FRAMING NOTE AND STAIR HT. 6'-8"				11/17	EH						
	INSTRUCTED OWNER TO REMOVE THE MICROHAIR OVEN WHERE BLOCKS THE REARMENT STAIR					EH						

RESIDENTIAL PLAN CORRECTION SHEET

CITY OF NAPOLEON
255 West Riverview Ave.
Napoleon, Ohio 43545
419/592-4010

ADDENDUM TO Permit No. 01271
Owner DOUG LANG
Contractor NAPOLEON CONSTRUCTION
Location 710 W. MAIN

Please note the items checked below and incorporate them into your plans as indicated: PERMIT NOT YET ISSUED, CORRECT PLANS AND RE-SUBMIT. PERMIT ISSUED, INCORPORATE ITEMS DURING CONSTRUCTION.

GENERAL			
<input checked="" type="checkbox"/>	Provide approved smoke detector(s) as req'd.		Show size of members supporting porch roof.
	Provide 1/2" gypsum wallboard between dwelling and garage, on garage side.		Provide double top plate for all bearing partitions and exterior walls.
	Provide min. 1 3/8" solid wood door from garage to dwelling. (or equal)		Provide design data for prefab wood truss.
	Submit fully dimensioned plot plan.		Ceiling joists undersized in _____.
	Provide min. of 1-3'0" x 6'8" exit door.		Roof rafters undersized in _____.
<input checked="" type="checkbox"/>	Provide min. 22" x 30" attic access opening.		PLUMBING AND MECHANICAL
<input checked="" type="checkbox"/>	Provide min. 18" x 24" crawl space access opening.	<input checked="" type="checkbox"/>	Terminate all exhaust systems to outside air.
	Provide approved sheathing or flashing behind masonry veneer.	<input checked="" type="checkbox"/>	Insulate ducts in unheated areas.
	Provide min. 15# underlayment on roof.	<input checked="" type="checkbox"/>	Provide backflow prevention device on all hose bibs.
<input checked="" type="checkbox"/>	Provide adequate fireplace hearth.	<input checked="" type="checkbox"/>	Terminate pressure and temperature relief valve drain in an approved manner.
	Install factory built fireplaces/stoves according to manufacturers instructions.		Provide dishwasher drain with approved air gap device.
<input checked="" type="checkbox"/>	Terminate chimney 2' above roof or 2' above highest point of building within 10' of chimney.		METAL VENEERS
	LIGHT AND VENTILATION		Contact City Utilities Dept. to remove conductors and/or meter.
	Provide mechanical exhaust or window in bathroom		Provide approved system of grounding and bonding.
	Provide min. <u>357</u> Sq. In. net free area attic ventilation.		ELECTRICAL
	Provide min. <u>357</u> Sq. In. net free area crawl space ventilation.		Show location of service entrance panel and service equipment panel.
	FOUNDATION		G. F. C. I. req'd. on temporary electric.
	Min. depth of foundation below finished grade is 32".	<input checked="" type="checkbox"/>	Outdoor, bathroom and garage receptacles shall be protected by G. F. C. I.
	Min. size of footer _____" x _____".		Maximum number of receptacles permitted on a G. F. C. I. circuit shall be 10 for 20 A. circuits and 7 for 15A. circuits.
<input checked="" type="checkbox"/>	Provide anchor bolts, 1/2" @ 6' o.c. 1' from each corner. Embedded 7" in concrete and 15" in masonry.		Refrigerators, microwaves, washers, disposal, furnace and air conditioners shall be on separate circuits.
	Show size of basement columns.		INSPECTIONS
	FRAMING		The following indicated inspections are required. The owner or his agent shall contact the City Building Dept. at least 24 hrs prior to the time the inspection is to be made.
	Show size of wood girder in _____.	<input checked="" type="checkbox"/>	Footers and Setbacks.
	Provide design data for structural member in _____.	<input checked="" type="checkbox"/>	Foundation.
	Floor joists undersized in _____.	<input checked="" type="checkbox"/>	Plumbing rough-in.
	Provide double joists under parallel bearing partitions.	<input checked="" type="checkbox"/>	Plumbing final.
<input checked="" type="checkbox"/>	Provide 1" x 4" let in corner bracing, approved sheathing, or equal.	<input checked="" type="checkbox"/>	Electrical service.
	Show size of headers for openings over 4' wide _____.	<input checked="" type="checkbox"/>	Electrical rough-in.
		<input checked="" type="checkbox"/>	Electrical final
		<input checked="" type="checkbox"/>	Building sewer.
		<input checked="" type="checkbox"/>	HVAC rough-in.
		<input checked="" type="checkbox"/>	Final Building other,
		<input checked="" type="checkbox"/>	<u>BUILDING FRAMING</u>

Additional Corrections. MIN. STAIR CEIL. HT = 6'-8" MAX RISE = 8 1/4"
MIN. TR. = 9" HAND RAIL IS REQ ON ONE SIDE PROVIDED SOLID
WOOD FLOORING BTWN 2ND FLOOR JOISTS AT THE WEST WALL
WHERE THEY SUPPORT THE BALCONY

The approval of plans and specifications does not permit the violation of any section of the Building Code or other City Ordinance. This addendum is attached to Permit No. 01271 and made a part thereof. DATE APPROVED OR DISAPPROVED 11-5-86 Checked by 54

Plan Examiner.

DATE RECHECKED AND APPROVED _____

Checked by _____

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

01271

Permit No. Issued date
 Job Location 710 W. MAIN address
 Lot 160 SHEFFIELD'S THIRD ADD sub-div or legal discript
 Issued By F building official
 Owner 0004 LANG 592-5601 name tel.
 Address 710 W. MAIN
 Agent NAPOLEON CONCRETE 592-7796 builder-eng.-etc. tel.
 Address N. SCOTT ST.
 Description of Use RESIDENCE
 Residential 1 no. dwelling units
 Commercial Industrial
 New Add'n. X Alter Remodel
 Mixed Occupancy
 Change of Occupancy
 Estimated Cost \$ 20,000.00

FEE	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING	3.00	36.00	39.00
<input checked="" type="checkbox"/> ELECTRICAL	5.00	8.00	13.00
<input type="checkbox"/> PLUMBING			
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> DEMOLITION			
<input type="checkbox"/> ZONING			
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs	Elect. _____ hrs	
TOTAL FEES.....			52.00
LESS MIN. FEES PAID _____ date _____			
BALANCE DUE.....			

ZONING INFORMATION

district	lot dimensions	area	front yd	side yds	rear yd
B	38.85' ± x 132' ±	4905 S.F.	25' MIN.	5' MIN.	15' MIN.
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr
35' MAX	2-MIN.		45' MAX.		

WORK INFORMATION:

Size: Length 22'-6" Width 19'-0" Stories 2 Ground Floor Area 3715 S.F.
 Height 24'-0" Building Volume (for demo. permit) _____ cu. ft.

Electrical: APPLY FOR SEPARATELY ADD APPROX 8 CIRCUITS
 brief description
 Plumbing: APPLY FOR SEPARATELY
 brief description
 Mechanical: APPLY FOR SEPARATELY
 brief description

Sign: N.A.I. Dimensions _____ Sign Area _____
 type

Additional Information: 2-STORY ADDITION TO THE NORTH END OF THE EXISTING RESIDENCE

Date _____ Applicant Signature _____ owner-agent

