

**PERMIT**

**CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING**

**255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010**

Permit No. 0941 Date Nov. 6, 1984  
 Job Location 755 W. Main Valuation \$ 400.00  
 Owner Sonny Tonjes Address 755 W. Main  
 Contractor \_\_\_\_\_ Telephone No. \_\_\_\_\_  
 Address \_\_\_\_\_  
 Electric Contractor Mikes Electric E. Riverview 592-8356  
 Plumbing Contractor \_\_\_\_\_  
 Mechanical Contractor \_\_\_\_\_

**This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.**

**Work Information:**

Residential 2 Family Commercial \_\_\_\_\_ Industrial \_\_\_\_\_  
No. dwelling units  
 New Construction \_\_\_\_\_ Addition \_\_\_\_\_ Remodel \_\_\_\_\_  
 Brief Description of Work Install 2 new 100 amp services

ISSUED BY Richard G. Kayman DEPT. OF BUILDING & ZONING  
Building Official

**It is the owners or contractors responsibility to call the Building Department for the following (X) inspections:**

- Footing excavation prior to placing concrete.
- Footing drains and foundation prior to backfill.
- Prepared sub-grade prior to placing concrete floor slab.
- Sanitary sewer
- Rough-in electrical, plumbing and service framing prior to installing wall board.
- Final electrical, plumbing and heating.
- Final building inspection, prior to occupancy.

**PERMIT & FEES**

Building Permit	\$ _____
Electrical Permit	\$ <u>5.00</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other	\$ _____

TOTAL FEES \$ 5.00  
 LESS FEES PAID \$ 0.00  
 BALANCE DUE \$ 5.00

**PAID**  
 JUN 12 1985  
 CITY OF NAPOLEON

**Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.**

UNITED STATES DEPARTMENT OF JUSTICE  
FEDERAL BUREAU OF INVESTIGATION

1983

TO : SAC, NEW YORK  
FROM : SAC, PHOENIX  
SUBJECT: [Illegible]

Re Phoenix teletype to New York dated 1/15/83.  
Enclosed for New York are two copies of a letterhead memorandum  
dated 1/15/83 and captioned as above.

Very truly yours,  
Special Agent in Charge

OFFICE OF THE DIRECTOR  
FEDERAL BUREAU OF INVESTIGATION  
B W I D

**PERMIT**

**CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING**  
**255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010**

Permit No. 0741 Date Nov 8, 1984  
Job Location 755 W. Main Valuation \$ 400.00  
Owner Sonny Tomlin Address 755 W. Main  
Contractor \_\_\_\_\_ Telephone No. \_\_\_\_\_  
Address \_\_\_\_\_  
Electric Contractor Electric E. Riverview 592-8356  
Plumbing Contractor \_\_\_\_\_  
Mechanical Contractor \_\_\_\_\_

**This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.**

**Work Information:**

Residential 2 Family Commercial \_\_\_\_\_ Industrial \_\_\_\_\_  
No. dwelling units  
New Construction \_\_\_\_\_ Addition \_\_\_\_\_ Remodel \_\_\_\_\_  
Brief Description of Work Install 2 new 100 amp services

ISSUED BY \_\_\_\_\_ DEPT. OF BUILDING & ZONING  
Building Official

**It is the owners or contractors responsibility to call the Building Department for the following (x) inspections:**

- \_\_\_\_\_ Footing excavation prior to placing concrete.
- \_\_\_\_\_ Footing drains and foundation prior to backfill.
- \_\_\_\_\_ Prepared sub-grade prior to placing concrete floor slab.
- \_\_\_\_\_ Sanitary sewer
- \_\_\_\_\_ Rough-in electrical, plumbing and service framing prior to installing wall board.
- \_\_\_\_\_ Final electrical, plumbing and heating.
- \_\_\_\_\_ Final building inspection, prior to occupancy.

**PERMIT & FEES**

Building Permit	\$ _____
Electrical Permit	\$ <u>5.00</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other _____	\$ _____

TOTAL FEES	\$ <u>5.00</u>
LESS FEES PAID	\$ <u>0-</u>
BALANCE DUE	\$ <u>5.00</u>

**Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.**

**PAID**  
**JUN 12 1985**  
**CITY OF NAPOLEON**

# INSPECTION RECORD

UNDERGROUND		ROUGH-IN &			FINAL	
Type	Date	By	Type	Date	By	Date
<b>PLUMBING</b>	Sewer Connection		Drainage, W. & Vent			Drainage, W. & Vent
	Building Sewer		Water Piping			Water Heater
	Water Piping		Condensate Lines			Backflow Prevention
			Indirect Waste			
<b>ELECTRICAL</b>	Floor Ducts Raceways		Rough Wiring			FINAL APPROVAL
	Conduits & or Cable		Conduits/Cable			Electric Mtr. Clearance
	Grounding & or Bonding		Service Panel			Signs
			Switchboard			
<b>MECHANICAL</b>	Refrigerant Piping		Subpanels			
	Ducts/Plenums		□ Range □ Dryer			FINAL APPROVAL
			Refrigerant Piping			Duct Insulation
			Ducts/Plenums			Chimney(s)
<b>BUILDING</b>			Ventilation □ Supply □ Exhst.			Furnace(s)
	Location, Set-backs, Esmt(s)		Wall Construction			FINAL APPROVAL
	Excavation		Crawl Space □ Vent □ Access			Fireplace Chimney
	Footings & Reinforcing		Floor System(s)			Attic □ Vent □ Access
		Sub-soil Drain	Roof System			Special Insp Reports Rec'd
		Foundation Walls	Fire Wall(s)			Smoke Detector
		Floor Slab	Roof Cover Roof Drain			Demolition (sewer cap)
FINAL APPROVAL		BLDG. DEPT		Certificate of Occupancy Issued		#

DIA 9  
 PREP & MUL  
 REZ DE SALOTTED

CITY OF NAPOLEON  
BUILDING INSPECTION DEPARTMENT  
APPLICATION FOR ELECTRICAL PERMIT  
(Please print or type)

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name Sonny Toujles Address 755 W MAIN

Electrical Contractor Mike's EL Telephone No. 592-8856

Address E RIVERVIEW

General Contractor \_\_\_\_\_ Telephone No. \_\_\_\_\_

Address \_\_\_\_\_

Location of Project 755 W MAIN Cost of Project \$400.00

Work Information:

Residential 2 Commercial \_\_\_\_\_ Industrial \_\_\_\_\_

No. Units

New \_\_\_\_\_ Service Change X Rewiring \_\_\_\_\_ Additional Wiring \_\_\_\_\_

Brief Description of Work: \_\_\_\_\_

Size of proposed service entrance 200 Number of new circuits 0

Type of proposed service entrance \_\_\_\_\_ Underground \_\_\_\_\_ Overhead X

Require Temporary Electric NO (Yes or No)

Total Floor Area - Commercial and Industrial only \_\_\_\_\_ sq. ft.

Additional Information: \_\_\_\_\_

\*Ground fault circuit interrupter protection is required on all 120-volt single phase, 15 and 20 amp. Circuits which are part of a temporary electric service: and also on bathroom, outdoor, and garage receptacles in all dwelling units. Art. 210-8 N.E.C.

\*Application for permit shall be accompanied by two complete sets of plans including: Electrical layout and riser diagram. (For commercial and industrial work only).

Date 11-6-84

Applicant's Signature [Signature]

PERMIT NO. 941

PERMIT FEE \$ 500



# CITY OF NAPOLEON WORK ORDER

Nº 60316

Dept. *Electric*

Name *Howard Longe*

Date Ordered *11-6-84*

Address *753 West Main*

By ~~Mike~~ *Richard Hayman*

LOCATION	Remove			Meter		Install	
	No.	Date	Vol.	No.	Date	Rdg.	
Electric							
Water							
Water Hr.							

request: *Tomorrow morning he will call to have disconnected - Mike Spencer*


Date Completed ..... By .....







# City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE - (419) 592-4010  
NAPOLEON, OHIO 43545-0151

October 16, 1984

**Mayor**

Robert G. Heft

**Clerk-Treasurer**

Rupert W. Schweinhagen

**Members of Council**

Darel Auster Miller, President

William Young

Lawrence Haase

Darrell Fox

Donald Morford

Lynn Wachtmann

**City Manager**

Richard A. Hayward

**Law Director**

Keith P. Muehlfeld

Clayton L. Tonjes  
167 Bradford  
Napoleon, Ohio 43545

Dear Mr. Tonjes:

The replacement of the meter and service disconnects on your house at 755 W. Main was installed without a permit and not according to the City Code or the National Electric Code.

All residential dwelling within the City are required to have a 100 amp service when they are being replaced or repaired. The two new 70 amp disconnect boxes that were installed are not legal under City Codes.

These disconnects will have to be removed and replaced with 100 amp disconnects. A permit will also have to be issued prior to the commencing of work.

These services shall be replaced within 15 days of this notice or legal action shall be taken to correct this violation.

Your cooperation is requested in this matter.

Yours truly,

Richard G. Hayman  
Building Inspector

RGH:mt



755 W. Main

MEMO:

About the 27 or 28 of September, Groll was removing a tree for the City on Sheffield near W. Main. The tree or a branch fell and tore the service off the rear of 755 W. Main St. . The house is a two family and had two 60 amp services at the rear corner of the dwelling next to the garage. Sonny Tonjes is the owner of the house and they called Mike Speicer to replace the services. One of the two services were damaged to the point where it could not be replaced, so Mike installed two new meter sockets and two new 70 amp disconnects. The electric dept. called me because they were contacted to hook up the service. Mike was not there when I went out and I told Mrs. Tonjes that the services would have to be changed to 100 amp. which is required by code. I saw Mike a couple of days later and told him. He said the insurance company would only pay for what was there before. I told Mike that if he had replaced the old equipment then they could leave it at 60 amps, but since they had installed new meter sockets and disconnects then it would have to be brought up to code. On October 16 1984 I sent a letter to Tonjes that the service would have to be changed to 100 amp and that a permit was not taken out for the first work and that one would have to be taken out for this change. Mike talked to me a week or so later and said he had the equipment to change the services but that it would take about a week or two before he could get to it. On Nov. 7, 1984 I got a call to inspect 755 W. Main. Upon inspection ,the wire size in the meter socket to the disconnect looked small and I asked Mike the size. He said it was #4. I told him it had to be #2 . He changed it and by 2:30 that afternoon they hooked up the service. Mrs. Tonjes complained about the cost and said if Groll had not tore the service down she would not have this expense. I told her to contact Groll that he has insurance.



