




906 W. MAIN ST.




4-20-15

INSP. : MARK SPIESS
INVESTIGATION OF ILLEGAL
SEWER CONNECTION.
BUILDING HAS GUTTERS
BUT NO DOWN SPOUTS.
NO TILE FOR DOWN SPOUTS
TO GO INTO.



0%
STAND
PIPE
w/ CONC.



30" Stm.




W. MAIN ST

27" Stm.



8" W.M.



901