

From: damman
To: TRACY
Date sent: Tue, 28 Aug 2001 17:00:52 -0400
Subject: Possible sewer problem at 816 Maple St.

Gary B. and (I think Ed M.) investigated a sinking driveway slab several months ago at 816 Maple St.. Could you ask them to contact me as to what was determined. It appeared to be related to the sanitary sewer main in the street. I believe they said there may be tree roots in the main.

Thanks

08-29-01 AM

Brent

Put the TV in and marked the TAP
in front of house. The tap goes to the west.
Marked in green paint. No TAP for 816 Maple.
Their tap must go out of the back and tie into
the interseptor.

RAY