

**CITY OF NAPOLEON
BUILDING CONSTRUCTION PERMIT
(1, 2 or 3 Family Dwelling)**

Owner Name Mrs. Mary K. Hartz

Address 111 East Maumee Ave.

Builder Name Harold Postelman Electrical Co.

Address 618 Park St. Tel. 592-2383

Lot Information:

Street No. 111 East Maumee Ave.

Lot # Subdivision J.O. Lowes 1st. Add'n.

Lot Dimensions Lot Area Sq. Ft.

Yard Set Back: Front Rear

Side Side

Zoning "R3" Intended use of Building: Installing in the front of the existing dwelling a new 100AMP. service entrance, new main distribution panel located in the basement and re-wiring entire building.

Building Information:

Single Double Multiple New Construction Addition Remodel

Size: Length 578 Width 67' No. of Stories 1

Floor Area: 1st Floor 2nd Floor 3rd Floor Basement

Unfinished Attic Garage

Foundation: Piers Full Basement Part Basement

Concrete Block

Walls: Frame Block Brick Other

Electrical: Wiring 100 AMP. Electric Heating Electrical Appliances (2)

Plumbing: Fixtures or Traps Warm Air Heating Hot Water Heating

Additional Information: This permit requires compliance with the attached addendum marked exhibit "A" and made a part here-of.

Date 4/24/75 Applicant Signature Harold Postelman

Owner - Builder - Agent

Inspection Record: Final: Electrical inspected & tested by Howes 5/11 owner informed to protect wiring in basement which would be subject to mechanical damage.

Work Started Foundations Plumbing, Heating

Set Back, Side Lines Plumbing (Rough In) And Air Conditioning

Excavation Erecting Frame Roof

Footing Electrical Work

Comments: 4/24/75 - Harold informed by Howes 4/24/75 Service & Rough-in inspected & approved Final Inspection Required & to contact City when ready. AWJ.

Certificate of Occupancy Issued

Inspector

Permit No.	<u>215-75</u>			
Issued	<u>3/10/75</u>			
By	<u>Howes W. Howes</u> Building Inspector			
Valuation	<u>\$1,200</u>			
	Fees	Base	Plus	Total
Construction				
Plumbing				
Electrical	<u>\$3.00</u>	<u>\$6.75</u>		<u>\$9.75</u>
Heating				
Water Tap				
Sewer Tap				
Temporary Elec.	<u>G.P.I.C. REQUIRED</u>			
TOTAL	<u>\$3.00</u>	<u>\$6.75</u>		<u>\$9.75</u>

CITY OF NAPOLEON
Engineering Department
 255 Riverview Avenue
 NAPOLEON, OHIO 43545

TO H. Bostelman

DATE <u>3-13-75</u>	JOB NO. <u>215-75</u>
PROJECT <u>BARTZ MRS MARJE</u>	
LOCATION <u>111 EAST MAUMEE</u>	
CONTRACTOR <u>BOSTELMAN</u>	OWNER <u>Bartz</u>
WEATHER	TEMP. ° at AM ° at PM
PRESENT AT SITE CITY OF NAPOLEON ENGINEERING DEPT. PLAN APPROVAL BY <u>NH</u> DATE <u>3-13-75</u>	

THE FOLLOWING WAS NOTED:


- 1. Consideration to Plan Approval:
 - a. Particular attention is directed to:
 - 1. Electrical wiring, equipment and installation shall conform to the requirements of the National Electric Code, 1971 issue, and is subject to the approval of the City Electrical Inspector.
 - 2. Location of Service Article 230-7c (a & b)
 - 3. Location of receptacles 210-22 (B)
 - 4. Wiring for Energy Switching may be 14/50 w/cwt.
 - 5. Outlet for Repts. Article 210-22 (B) and paragraph
 - 6. Neutral conductors of devices have to be continuous.
 - 7. Number of conductors in outlet box. Article 370-6.
 - 8. Your possession of information by drawing is inadequate; future drawings for approval must be more informative to customer's service.

Service & Rough-in inspected & approved

FIELD REPORT

SIGNED Norman Hones

City when ready...



Mr. Postelman:

Monday March 4, 1975

Dear Sir:

Re Bartz rewiring house-and the drawing you submitted. We, need the following information-concerned there to.

No. 1 Total cost of job.?

Answer: 1200.00

No. 2 Grounding to (water line) and grounding rod?

Answer: Meter to Grounding rod + panel to Water line

No. 3 Indicate of each room in building. *shown on drawing*

Answer: *sheet*

No. 4 Show outside dimensions to building,?

Answer. 57 ft By 57 feet

No. 5 Submit Riser diagram? *Electrical*

Answer; 7 Step Riser Outside to basement - also seven step inside from B/R to basement

No. 6 Indicate kitchen layout? Counter tops, range etc.

Answer: Range on south end of kitchen - Rfge to side it - Cupboard - work bench along wall next to porch - SINK

No. 7 Indicate number of 20 Amp circuits in kitchen area and Family Rm

Ans. 2 20 amp circuits and 1 50 Amp Range receptacle.

No. 8 Distance and location of main Panel from meter.

Answer: Panel will be in Veg Room (see plan) - about 7 feet from meter

No. 9 Height of mast from Grade.? 15 feet.

6' max.

Answer;

No 10 Name and address and phone number of contractor?

ans HAROLD POSTELMAN, 618 Park St- Napoleon Ohio 592-2383

Note 110Vlt Washer receptacle - and 2 20Vlt dryer receptacles - also

Rush.

100 - 100



OWNER: Mrs. Bartz
Location: 111 E. Maumee Ave.
Contractor: Harold Bostelman
Bldg Permit No. 215-75