

**CITY OF NAPOLEON  
BUILDING CONSTRUCTION PERMIT  
(1, 2 or 3 Family Dwelling)**

Owner Name William Pirdson  
 Address 153 E. Maumee Ave.  
 Builder Name Harold Bostelman  
 Address 618 Park St. Nap. O. Tel. 592-2383

**Lot Information:**

Street No. 153 E Maumee Ave.  
 Lot --- Subdivision -----  
 Lot Dimensions --- Lot Area --- Sq. Ft.  
 Yard Set Back: Front n/a Rear n/a  
 Side n/a Side n/a

Zoning "GB" Intended use of Building: New electric service.

2/17/77: KEN LANGE INFORMED BY HOWES SERVICE CONDUCTORS SHOULD BE HIGHER AND AWAY FROM CHIMNEY, PLUF.

**Building Information:**

Single  Double  Multiple  New Construction  Addition  Remodel   
 Size: Length --- Width --- No. of Stories 2  
 Floor Area: 1st Floor --- 2nd Floor --- 3rd Floor --- Basement ---  
 Unfinished Attic --- Garage ---  
 Foundation: Piers --- Full Basement --- Part Basement ---  
 Concrete --- Block ---

Walls: Frame --- Block --- Brick --- Other ---

Electrical: Wiring New 150 Amp Electric Heating --- Electrical Appliances ---

Plumbing: Fixtures or Traps --- Warm Air Heating --- Hot Water Heating ---

Additional Information: 2/17/77: RE-INSPECTED, HAZARDOUS CONDITIONS CORRECTED BY ELECTRICIAN. INSPECTED AND APPROVED BY HOWES.

Date 1/27/77 Applicant Signature Harold Bostelman

NOTE: 1/27/77 HOWES INFORMED OWNER AND CONTRACTOR OF THE HAZARDOUS CONDITON OF THE EXISTING WIRING SYSTEM AND IT SHOULD BE CORRECTED TO CONFORM WITH N.E.C. 75 EDITION, PLUF.

**Inspection Record:**

Work Started --- Foundations --- Plumbing, Heating ---  
 Set Back, Side Lines --- Plumbing (Rough In) --- And Air Conditioning ---  
 Excavation --- Erecting Frame --- Roof ---  
 Footing --- Electrical Work SERVICE & PANEL INSPECTED AND APPROVED BY HOWES 1/27/77

Comments: 1/27/77 HAROLD BOSTELMAN INFORMED CONTACT BLDG DEPT. FOR A FINAL ELECTRICAL INSPECTION, PLUF

Certificate of Occupancy Issued --- Inspector ---

Permit No. 652-77

Issued 2/7/77

By Thomas W. Brennan  
 Building Inspector

Valuation \$500.00

Fees	Base	Plus	Total
Construction			
Plumbing			
Electrical	\$3.00	---	\$3.00
Heating			
Water Tap			
Sewer Tap			
Temporary Elec.			
<b>TOTAL</b>	<b>\$3.00</b>	<b>---</b>	<b>\$3.00</b>

Date: January 6-1977

TO: The Building Inspector - Engineering Dept.

FROM: Electric Distribution Superintendent

Confirmed the installation of 150 AMP. electrical service entrance, located Far back corner west side towards chiefs at top of Roof line at the following address: 153 E Maumee

Approved C

Not Approved \_\_\_\_\_

K. Change  
Electric Supt.

1-6-77

Date

Remarks: A Bostonian electrician: have 200 amp socket for this job.

651-77  
**RECEIVED**

**JAN 7 1977**

CITY OF NAPOLEON  
BUILDING INSPECTION DEPARTMENT  
APPLICATION FOR ELECTRICAL PERMIT  
(PLEASE PRINT OR TYPE)

CITY OF NAPOLEON  
BUILDING DEPT.

BY: T.W.T.

The undersigned hereby makes application for the installation, replacement, or alteration of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Code for 1, 2 and 3 Family Buildings.

Owner's Name WILLIAM FIRSDON Address 153 EAST MAUMEE

Contractor's Name HAROLD BOSTELMAN Address 618 PARK Tel. 592-2383

LOT INFORMATION:

Location of Project 153 EAST MAUMEE Zoning District \_\_\_\_\_

BUILDING INFORMATION:

Single Family  Double Family \_\_\_\_\_ Multiple Family \_\_\_\_\_

New Construction \_\_\_\_\_ Existing \_\_\_\_\_ Addition \_\_\_\_\_

Replacement  Remodel \_\_\_\_\_ Service Change

Size: Total Square Foot Per Floor \_\_\_\_\_ No. of Stories 2

DESCRIPTION OF WORK

Size of Service 150 AMP. Service Change Only yes (Yes or No)

Total Number of New Circuits 12 Total Number of New Circuits Excluding Appliance Circuits 6

APPLIANCE CIRCUITS: (indicate quantity)

Electric Range  Range Hood \_\_\_\_\_ Clothes Dryer  Dishwasher \_\_\_\_\_

Air Conditioner  Attic Fan Blower \_\_\_\_\_ Room Exhaust Fan \_\_\_\_\_

Disposal \_\_\_\_\_ Hot Water Heater \_\_\_\_\_ Electric Oven \_\_\_\_\_

Require Temporary Electric No (Yes or No)

Note: G.F.I.C. required for all temporary electric with approved ground rod at service.

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAY-OUT AND RISER DIAGRAM.


ESTIMATED COST OF COMPLETED PROJECT: 500.00

DATE Jan. 6, 1977 APPLICANT'S SIGNATURE Harold Bostelman

OWNER-CONTRACTOR-AGENT

WILLIAM FIRSDON  
153 EAST MAUMEE

JAN. 6-1977



2" RIGID-CONDUIT  
3 # 1-0 THW COPER

RECEIVED

JAN 7 1977

CITY OF NAPOLEON  
BUILDING DEPT

BY T.W.T.

CITY OF NAPOLEON  
BUILDING DEPT.

Plan Approval

By \_\_\_\_\_ Date 1/7/77

150 AMP. →  
20 CIR.  
PANEL

IN-BASEMENT