



City of Napoleon, Ohio

Department of Public Works

255 West Riverview Avenue, P.O. Box 151

Napoleon, OH 43545

Chad E. Lulfs, P.E., P.S., Director of Public Works

Telephone: (419) 592-4010 Fax: (419) 599-8393

www.napoleonohio.com

June 19, 2015

7023 Shooter Hill
Toledo, OH 43617

Attn: Prime, L.L.C.

Re: 179 E. Maumee Avenue Sewer Connection

To whom it may concern,

It has been confirmed that the above referenced property has illegal sewer connections. During a sewer investigation, two catch basins dyed positive to the sanitary sewer. This violates Rule 26.4 of the City of Napoleon Rules for Water and Sewer Service:

“Wrongful Discharge Into Sanitary Sewers

Except for condensation water discharge from residential furnaces or cooling systems, it shall be a violation of these Rules for any person, regardless of intent, to discharge or cause to be discharged any unpolluted waters such as stormwater, groundwater, roof runoff, subsurface drainage, or cooling water to any City owned or operated or controlled sanitary sewer.”


These connections must be cut off and permanently capped from the sanitary sewer. The catch basins will either need to be removed or redirected to flow into the storm sewer. Per Rule 27 (C):

“Any person found violating Rules...26.4... shall be deemed guilty of a misdemeanor of the minor degree and the penalties as contained in Chapter 501.99 of the Codified Ordinances of the City of Napoleon, Ohio shall apply. Each day a violation continues constitutes a separate violation.”

You are hereby given notice that you have 90 days from the date of this letter to perform the required corrective measures listed above. Please contact our office to arrange for all required inspections and specifications. Any questions you might have regarding this issue should also be forwarded to our office.

SCANNED

Yours truly,



Chad E. Lulfs, P.E., P.S.
Director of Public Works
City of Napoleon, Ohio

cc: Monica Irelan, City Manager
Trevor Hayberger, City Law Director
Jeff Rathge, Operations Superintendent
Marty Crossland, Staff Engineer

SCANNED